


FUEL REPORT

UNC ROCKINGHAM - 10K VST 6 IN

Component **Diesel Fuel**

DIESEL FUEL No. 2 (10000 GAL)





DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We advise that you inspect for the source(s) of rust. All other laboratory tests indicate that this sample meets specifications for No.2 lowsulfur diesel fuel.

Corrosion

Moderate concentration of visible metal present.

Contaminants

Moderate concentration of visible dirt/debris present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.


Fuel Condition

The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. Sulfur value derived by ASTM D5453 method for ULSD validation.

				Jul2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0787041		
Sample Date		Client Info		14 Jul 2023		
Machine Age	hrs	Client Info		0		
Sample Status				ABNORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.844		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445	4.1	2.53		
Pensky-Martens Flash Point	°C	*PMCC Calculated		59		
SULFUR CONTE	VT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		374		
Sulfur (UVF)	ppm	ASTM D5453		315		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		164		
5% Distillation Point	°C	ASTM D86		192		
10% Distill Point	°C	ASTM D86		203		
15% Distillation Point	°C	ASTM D86		213		
20% Distill Point	°C	ASTM D86		221		
30% Distill Point	°C	ASTM D86		235		
40% Distill Point	°C	ASTM D86		247		
50% Distill Point	°C	ASTM D86		260		
60% Distill Point	°C	ASTM D86		274		
70% Distill Point	°C	ASTM D86		288		
80% Distill Point	°C	ASTM D86		304		
85% Distillation Point		ASTM D86		313		
90% Distill Point	°C	ASTM D86		325		
95% Distillation Point Final Boiling Point	°C	ASTM D86 ASTM D86		342 351		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.7		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		36.2		
Cetane Index		ASTM D4737	<40.0	47.1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.005		
ppm Water	ppm	ASTM D6304	<500	59.8		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



FUEL REPORT







Laboratory Sample No. Lab Number Unique Number

: WC0787041 : 05902708 : 10564064

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 19 Jul 2023 Diagnosed : 18 Aug 2023

Diagnostician : Doug Bogart

Test Package : DF-2 (Additional Tests: Screen)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

VITAL FUEL SYSTEMS

1076 CLASSIC RD APEX, NC US 27539

Contact: JOHN MORREALE jmorreale@vitalfuelsystems.com

T: (919)629-8180 F: (919)303-7399