

OIL ANALYSIS REPORT

MAIN PLANT CMP-CMP02

Component

Compressor

COMPRESSOR OIL (PAG) ISO 46 (--- QTS)

Sample Rating Trend



Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			0et2020	Jul2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0830444	WC0516811	
Sample Date		Client Info		17 Jul 2023	23 Oct 2020	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		<1	<1	
Aluminum	ppm	ASTM D5185m	>25	0	0	
Lead	ppm	ASTM D5185m	>25	0	0	
Copper	ppm	ASTM D5185m	>50	4	1	
Tin	ppm	ASTM D5185m	>15	<1	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	0	<1	
Barium	ppm	ASTM D5185m	525	3	3	
Molybdenum	ppm	ASTM D5185m	10	0	<1	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	5	<1	4	
Calcium	ppm	ASTM D5185m	10	0	19	
Phosphorus	ppm	ASTM D5185m	250	387	477	
Zinc	ppm	ASTM D5185m	100	2	5	
Sulfur	ppm	ASTM D5185m	400	325	212	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	2	
Sodium	ppm	ASTM D5185m		3	3	
Potassium	ppm	ASTM D5185m	>20	<1	<1	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1114		
Particles >6µm		ASTM D7647	>2500	177		
Particles >14μm		ASTM D7647	>320	42		
Particles >21µm		ASTM D7647	>80	22		
Particles >38μm		ASTM D7647	>20	2		
Particles >71μm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	17/15/13		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.649	0.337	



OIL ANALYSIS REPORT







Certificate L2367

Laboratory

Sample No. Lab Number **Unique Number**

: 05903244 : 10564600 Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0830444 Received : 20 Jul 2023 Diagnosed : 24 Jul 2023

: Angela Borella Diagnostician

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

318 WEST GILMAN ST NEW YORK MILLS, MN US 56567

Contact: TODD PITMAN

todd.pitman@lundboats.com T:

Contact/Location: TODD PITMAN - LANNEW

F: