




PROBLEM SUMMARY

Sample Rating Trend




WEAR




Machine Id
HT 02
 Component
Agitator Gearbox
 Fluid
GEAR OIL LS 80W90 (--- LTR)

COMPONENT CONDITION SUMMARY

▲ Non-ferrous Metals



▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	---
Copper	ppm	ASTM D5185m >50	▲ 68	▲ 174	---
Particles >4µm		ASTM D7647 >20000	▲ 139669	▲ 241322	---
Particles >6µm		ASTM D7647 >5000	▲ 30755	▲ 131201	---
Particles >14µm		ASTM D7647 >640	▲ 1645	▲ 932	---
Particles >21µm		ASTM D7647 >160	▲ 427	▲ 16	---
Oil Cleanliness		ISO 4406 (c) >21/19/16	▲ 24/22/18	▲ 25/24/17	---

Customer Id: KRAMASIOW
 Sample No.: USP244677
 Lab Number: 05903279
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

16 Jan 2023 Diag: Jonathan Hester

WATER



We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. Please specify the brand, type, and viscosity of the oil on your next sample. The copper level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
HT 02
 Component
Agitator Gearbox
 Fluid
GEAR OIL LS 80W90 (--- LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USP244677	USP234438	---
Sample Date	Client Info		17 Jul 2023	16 Jan 2023	---
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			ABNORMAL	ABNORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >150	6	15	---
Chromium	ppm	ASTM D5185m >10	0	<1	---
Nickel	ppm	ASTM D5185m >10	0	0	---
Titanium	ppm	ASTM D5185m	0	0	---
Silver	ppm	ASTM D5185m	<1	0	---
Aluminum	ppm	ASTM D5185m >25	<1	1	---
Lead	ppm	ASTM D5185m >100	<1	<1	---
Copper	ppm	ASTM D5185m >50	▲ 68	▲ 174	---
Tin	ppm	ASTM D5185m >10	<1	<1	---
Vanadium	ppm	ASTM D5185m	0	0	---
Cadmium	ppm	ASTM D5185m	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 150	22	28	---
Barium	ppm	ASTM D5185m	1	0	---
Molybdenum	ppm	ASTM D5185m	1	0	---
Manganese	ppm	ASTM D5185m	<1	1	---
Magnesium	ppm	ASTM D5185m 10	<1	3	---
Calcium	ppm	ASTM D5185m 70	2	5	---
Phosphorus	ppm	ASTM D5185m 2000	751	1335	---
Zinc	ppm	ASTM D5185m 50	16	57	---
Sulfur	ppm	ASTM D5185m 20000	12646	22907	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	11	12	---
Sodium	ppm	ASTM D5185m	0	<1	---
Potassium	ppm	ASTM D5185m >20	<1	<1	---
Water	%	ASTM D6304 >0.1	0.006	▲ 0.164	---
ppm Water	ppm	ASTM D6304 >1000	65.2	▲ 1640	---

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 139669	▲ 241322	---
Particles >6µm	ASTM D7647	>5000	▲ 30755	▲ 131201	---
Particles >14µm	ASTM D7647	>640	▲ 1645	▲ 932	---
Particles >21µm	ASTM D7647	>160	▲ 427	16	---
Particles >38µm	ASTM D7647	>40	15	2	---
Particles >71µm	ASTM D7647	>10	1	1	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/22/18	▲ 25/24/17	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.56	3.23	---




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	0.2%
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	140	200	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP244677 **Received** : 20 Jul 2023
Lab Number : 05903279 **Diagnosed** : 21 Jul 2023
Unique Number : 10564635 **Diagnostician** : Doug Bogart
Test Package : IND 2

KraftHeinz - Mason City - Plant 8360
 1022 12TH ST
 MASON CITY, IA
 US 50401
 Contact: Service Manager

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)