

### **PROBLEM SUMMARY**

Sample Rating Trend




# KAESER AIR CENTER SX 5 5792136 (S/N 1603)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status		ABN	ORMAL ABNO	RMAL ABNORMAL						
Particles >6μm	ASTM D7647 >	·1300 <b>△ 25</b>	<b>840</b> $\triangle$ 497	8 4 3753						
Particles >14μm	ASTM D7647 >	80 🔺 41	<b>89</b> $\triangle$ 569	<b>▲</b> 462						
Particles >21µm	ASTM D7647 >	·20 <b>_ 14</b>	<b>02</b> $\wedge$ 170	<u></u> 152						
Particles >38µm	ASTM D7647 >	-4 <b>^68</b>	<u> 11</u>	<b>4</b> 9						
Oil Cleanliness	ISO 4406 (c) >	/17/13 <u>^</u> <b>23</b>	<b>/22/19</b> <u> ^ 21/</u> 1	19/16 🔺 19/16						

Customer Id: OLDBET Sample No.: KC107751 Lab Number: 05903288 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

### HISTORICAL DIAGNOSIS

### 16 Jun 2022 Diag: Don Baldridge





Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 01 Jun 2021 Diag: Angela Borella

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 23 Sep 2020 Diag: Angela Borella

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





### **OIL ANALYSIS REPORT**

**Sample Rating Trend** 



Machine Id

## KAESER AIR CENTER SX 5 5792136 (S/N 1603)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### **DIAGNOSIS**

### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb2018	Jan2019 Nov2019 :	Sep2020 Jun2021 Jun2022	Jul2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC107751	KC104189	KC88800
Sample Date		Client Info		16 Jul 2023	16 Jun 2022	01 Jun 2021
Machine Age	hrs	Client Info		56435	47107	37996
Oil Age	hrs	Client Info		9318	0	6014
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	18	22	9
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	14
Barium	ppm	ASTM D5185m	90	1	2	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	<1	1	2
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	6	<1
Zinc	ppm	ASTM D5185m		19	25	17
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		0	0	2
Potassium	ppm	ASTM D5185m	>20	1	<1	0
Water	%	ASTM D6304	>0.05	0.008	0.010	0.007
ppm Water	ppm	ASTM D6304	>500	84.5	102.7	74.3
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		54842	12077	11600
Particles >6µm		ASTM D7647	>1300	<b>25840</b>	<b>4978</b>	<u>▲</u> 3753
Particles >14µm		ASTM D7647	>80	<b>4189</b>	<b>▲</b> 569	<b>▲</b> 462
Particles >21µm		ASTM D7647	>20	<b>1402</b>	<u> 170</u>	<u>▲</u> 152
Particles >38µm		ASTM D7647	>4	<u></u> ▲ 68	<u> 11</u>	<u> </u>
Particles >71µm		ASTM D7647	>3	2	1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u></u>	<u>^</u> 21/19/16	<u>▲</u> 19/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
I LOID DEGNADA	HON	method	iiiiii/base	o 27	HISTORY	HISTORYZ

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.37

0.32

0.376



### **OIL ANALYSIS REPORT**





Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact:

T: F: