




# PROBLEM SUMMARY

Sample Rating Trend




**WATER**



Machine Id  
**KAESER AIRTOWER 5C 4359172 (S/N 1084)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Water



## RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	ABNORMAL	---
Water	%	ASTM D6304	>0.05	▲ <b>0.452</b>	0.029	---
ppm Water	ppm	ASTM D6304	>500	▲ <b>4520</b>	296.1	---
Debris	scalar	*Visual	NONE	▲ <b>MODER</b>	▲ MODER	---
Appearance	scalar	*Visual	NORML	▲ <b>HAZY</b>	NORML	---
Emulsified Water	scalar	*Visual	>0.05	▲ <b>0.2%</b>	NEG	---

**Customer Id:** SERENG  
**Sample No.:** KCPA002150  
**Lab Number:** 05903306  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

### 11 May 2021 Diag: Don Baldrige

#### VIS DEBRIS




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**KAESER AIRTOWER 5C 4359172 (S/N 1084)**

Component

**Compressor**

Fluid

**KAESER SIGMA (OEM) M-460 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### Wear

All component wear rates are normal.

### ▲ Contamination

Moderate concentration of visible dirt/debris present in the oil. There is a moderate concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCPA002150</b>	KCP31365	---
Sample Date	Client Info		<b>23 Jun 2023</b>	11 May 2021	---
Machine Age	hrs	Client Info	<b>4583</b>	1223	---
Oil Age	hrs	Client Info	<b>0</b>	384	---
Oil Changed	Client Info		<b>N/A</b>	Changed	---
Sample Status			<b>ABNORMAL</b>	ABNORMAL	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>&lt;1</b>	<1	---
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	---
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	---
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	---
Silver	ppm	ASTM D5185m >2	<b>&lt;1</b>	0	---
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	<1	---
Lead	ppm	ASTM D5185m >10	<b>&lt;1</b>	2	---
Copper	ppm	ASTM D5185m >50	<b>4</b>	3	---
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	---
Antimony	ppm	ASTM D5185m	<b>---</b>	0	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	21	---
Barium	ppm	ASTM D5185m 90	<b>18</b>	71	---
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	<1	---
Manganese	ppm	ASTM D5185m	<b>0</b>	0	---
Magnesium	ppm	ASTM D5185m 100	<b>49</b>	88	---
Calcium	ppm	ASTM D5185m 0	<b>&lt;1</b>	0	---
Phosphorus	ppm	ASTM D5185m 0	<b>1</b>	2	---
Zinc	ppm	ASTM D5185m 0	<b>2</b>	4	---
Sulfur	ppm	ASTM D5185m 23500	<b>22579</b>	20167	---




## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>1</b>	5	---
Sodium	ppm	ASTM D5185m	<b>6</b>	15	---
Potassium	ppm	ASTM D5185m >20	<b>3</b>	0	---
Water	%	ASTM D6304 >0.05	<b>▲ 0.452</b>	0.029	---
ppm Water	ppm	ASTM D6304 >500	<b>▲ 4520</b>	296.1	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>0.38</b>	0.339	---

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	▲ 0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	46.6	44.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA002150 **Received** : 20 Jul 2023  
**Lab Number** : 05903306 **Diagnosed** : 24 Jul 2023  
**Unique Number** : 10564662 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**SERVICE UNIFORM**  
 2580 S RARITAN ST  
 ENGLEWOOD, CO  
 US 80110  
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: