


PROBLEM SUMMARY

Sample Rating Trend




ISO



Area
PF RESIN
Machine Id
RX1 A1 AGITATOR (S/N 30292 7)
Component
Gearbox
Fluid
CHEVRON MEROPA 150 (1 GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Please resample in 30 days to validate whether the wear rate is steady, or still rising. The net Fe value is low, but is elevated over previous sample results. The oil should be filtered while the machine is running to control possible hard particles that could contribute to the wear increase.

PROBLEMATIC TEST RESULTS

| Sample Status | | | SEVERE | ABNORMAL | ABNORMAL |
|-----------------|-----|------------------------|------------|------------|------------|
| Boron | ppm | ASTM D5185m | ▲ 28 | 23 | 11 |
| Calcium | ppm | ASTM D5185m | ▲ 108 | 122 | ▲ 154 |
| Zinc | ppm | ASTM D5185m | ▲ 49 | 39 | ▲ 80 |
| Sulfur | ppm | ASTM D5185m | ▲ 14191 | 10124 | 6889 |
| Particles >4µm | | ASTM D7647 >20000 | ● 213411 | ▲ 92771 | ▲ 64763 |
| Particles >6µm | | ASTM D7647 >5000 | ● 58800 | ▲ 10975 | ▲ 7495 |
| Particles >14µm | | ASTM D7647 >640 | ▲ 3213 | 526 | 210 |
| Particles >21µm | | ASTM D7647 >160 | ▲ 735 | 172 | 35 |
| Oil Cleanliness | | ISO 4406 (c) >21/19/16 | ● 25/23/19 | ▲ 24/21/16 | ▲ 23/20/15 |
| Visc @ 40°C | cSt | ASTM D445 142 | ▲ 164.4 | 222 | 219 |

Customer Id: HEXLAG
Sample No.: PLS0000627
Lab Number: 05903695
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Mike Johnson +1 (615)771-6030
mike.johnson@amrri.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

28 Nov 2022 Diag: Mike Johnson

ISO



Filter oil if possible using the drum station filter. If filtration is not possible, consider flushing and filling the gearbox at next available opportunity. Poor sample quality could also be due to poor sample port location. Review that sample port is not being pulled from drain. Resample at next normal interval. Wear particles are low and acceptable. Particle contamination is significantly elevated. Filtration can help extend machine life. Fluid health is acceptable for continued use AS AN ISO 220 oil. Site has reported a change to ISO 150, but this sample is still `220` grade.

view report



11 Mar 2022 Diag: Doug Bogart

ADDITIVES



Filter oil with B6=75 filter media or better if possible. If oil cannot be filtered, consider changing oil at next available opportunity. Confirm that oil is correctly named on sample labels. Resample at next normal interval. Wear indicators are low but increasing, which can indicate an accelerated wear state. Particles $>4\mu\text{m}$ are abnormally high. Particles $>6\mu\text{m}$ are notably high. Calcium and Zinc indicators are elevated from expected values. This can be due to mixed oil types or contaminants from external sources. These indicators are relatively unchanged from the previous sample.

view report



31 Dec 2021 Diag: Mike Johnson

ISO




Filter oil if possible using B6=75 filter media or better. If filtering is not possible, consider changing oil at next available opportunity. Investigate possible contamination sources such as broken breathers, broken seals, or poor sampling techniques. Resample at next normal interval. Wear indicators are low and acceptable. Particle contamination is extremely elevated. Particle contamination on this level can significantly reduce machine life. Several additive numbers have noticeably changed from previous baselines indicating possible contamination or intermixing of different oils. This is a noticeable trend over time indicating that the buildup is most likely caused by contamination.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
PF RESIN
Machine Id
RX1 A1 AGITATOR (S/N 30292 7)
Component
Gearbox
Fluid
CHEVRON MEROPA 150 (1 GAL)

DIAGNOSIS

Recommendation

Please resample in 30 days to validate whether the wear rate is steady, or still rising. The net Fe value is low, but is elevated over previous sample results. The oil should be filtered while the machine is running to control possible hard particles that could contribute to the wear increase.

Wear

Iron wear rate is slightly elevated, and is well above the normal low trend.

Contamination

The particle count is substantially elevated. Filter the oil using B6=75 or better quality media.

Fluid Condition

The viscosity is slightly above the `alert` level of +10%. This could be caused by residual ISO 220 used previously. This is not a concern at this time. Other lubricant health parameters (additives, AN value, Ox-Ni-Su) suggest the oil is good for continued use.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | PLS0000627 | PLS0000630 | PLS0000310 |
| Sample Date | Client Info | | 18 Jul 2023 | 28 Nov 2022 | 11 Mar 2022 |
| Machine Age | yrs | Client Info | 39 | 39 | 39 |
| Oil Age | yrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | Not Changed | Not Changed | Not Changed |
| Sample Status | | | SEVERE | ABNORMAL | ABNORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|------------|------------------|--------------|----------|----------|
| PQ | ASTM D8184 | | 33 | 14 | 16 |
| Iron | ppm | ASTM D5185m >200 | 24 | 8 | 14 |
| Chromium | ppm | ASTM D5185m >15 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >15 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m >25 | <1 | 0 | <1 |
| Lead | ppm | ASTM D5185m >100 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185m >200 | 2 | 0 | 1 |
| Tin | ppm | ASTM D5185m >25 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185m >5 | --- | --- | --- |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | <1 | 0 | <1 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------|----------------|----------|----------|
| Boron | ppm | ASTM D5185m | ▲ 28 | 23 | 11 |
| Barium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 2 | <1 | 4 |
| Manganese | ppm | ASTM D5185m | <1 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m | 1 | 2 | 0 |
| Calcium | ppm | ASTM D5185m | ▲ 108 | 122 | ▲ 154 |
| Phosphorus | ppm | ASTM D5185m | 368 | 236 | 302 |
| Zinc | ppm | ASTM D5185m | ▲ 49 | 39 | ▲ 80 |
| Sulfur | ppm | ASTM D5185m | ▲ 14191 | 10124 | 6889 |






CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-----------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >50 | 2 | <1 | 1 |
| Sodium | ppm | ASTM D5185m | <1 | 0 | 0 |
| Potassium | ppm | ASTM D5185m >20 | 0 | <1 | 0 |

INFRA-RED

| | method | limit/base | current | history1 | history2 |
|-----------|----------|-------------|-------------|----------|----------|
| Soot % | % | *ASTM D7844 | 0 | 0.1 | 0 |
| Nitration | Abs/cm | *ASTM D7624 | 2.9 | 3.0 | 2.8 |
| Sulfation | Abs/.1mm | *ASTM D7415 | 12.4 | 13.0 | 12.7 |

OIL ANALYSIS REPORT




| FLUID CLEANLINESS | method | limit/base | current | history1 | history2 |
|-------------------|--------------|------------|-------------------|------------|------------|
| Particles >4μm | ASTM D7647 | >20000 | 🔴 213411 | 🟡 92771 | 🟡 64763 |
| Particles >6μm | ASTM D7647 | >5000 | 🔴 58800 | 🟡 10975 | 🟡 7495 |
| Particles >14μm | ASTM D7647 | >640 | 🟡 3213 | 526 | 210 |
| Particles >21μm | ASTM D7647 | >160 | 🟡 735 | 172 | 35 |
| Particles >38μm | ASTM D7647 | >40 | 34 | 27 | 0 |
| Particles >71μm | ASTM D7647 | >10 | 3 | 6 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | 🔴 25/23/19 | 🟡 24/21/16 | 🟡 23/20/15 |

| FLUID DEGRADATION | method | limit/base | current | history1 | history2 |
|-------------------|----------------------|------------|-------------|----------|----------|
| Oxidation | Abs/.1mm *ASTM D7414 | | 3.8 | 3.2 | 3.2 |
| Acid Number (AN) | mg KOH/g ASTM D8045 | | 0.67 | 0.64 | 0.43 |

| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|----------------|------------|--------------|----------|----------|
| White Metal | scalar *Visual | NONE | LIGHT | NONE | NONE |
| Yellow Metal | scalar *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar *Visual | NONE | NONE | LIGHT | NONE |
| Sand/Dirt | scalar *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar *Visual | >0.2 | NEG | NEG | NEG |
| Free Water | scalar *Visual | | NEG | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|---------------|------------|----------------|----------|----------|
| Visc @ 40°C | cSt ASTM D445 | 142 | 🟡 164.4 | 222 | 219 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PLS0000627
Lab Number : **05903695**
Unique Number : 10565051
Test Package : IND 2 (Additional Tests: FT-IR, PQ, PrtCount)

HEXION INC - LA GRANDE PLANT
 62575 OREGON HWY 82
 LA GRANDE, OR
 US 97850
 Contact: IAN PARKS
 ian.parks@hexion.com
 T: (541)963-7155
 F: (541)963-0957

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)