



Machine Id 7386399 (S/N 1643)

COMPRESSORS Built for a lifetime."

Component Compressor Fluid KAESER SIGMA (OEM) FG-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	NORMAL	NORMAL		
Water	%	ASTM D6304	>0.05	0.208	0.010	0.006		
ppm Water	ppm	ASTM D6304	>500	<u> </u>	107.2	63.9		
Appearance	scalar	*Visual	NORML	🔺 HAZY	NORML	NORML		

Customer Id: UNLWHI Sample No.: KC05903777 Lab Number: 05903777 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

12 Apr 2023 Diag:



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

27 Jan 2023 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





27 Dec 2021 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT





7386399 (S/N 1643) Component **Compressor**

KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Machine Id

A Recommendation

The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Appearance is hazy. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM		method	limit/base	current	history i	nistory2
Sample Number		Client Info		KC05903777	KC05832705	KC96379
Sample Date		Client Info		10 Jul 2023	12 Apr 2023	27 Jan 2023
Machine Age	hrs	Client Info		2610	1940	526
Oil Age	hrs	Client Info		0	0	349
Oil Changed		Client Info		N/A	N/A	Changed
Sample Status				ABNORMAL	NORMAL	NORMAL
		mothod	limit/base	ourroat	biotomat	biotom/0
WEAR METALS		method	inniv base	current	nistory i	nistory2
Iron	ppm	ASTM D5185m	>50	4	1	9
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	8	2	8
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	0	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		2	3	1
Calcium	ppm	ASTM D5185m		2	2	<1
Phosphorus	ppm	ASTM D5185m	500	450	476	426
Zinc	ppm	ASTM D5185m		110	76	230
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	maa	ASTM D5185m	>25	0	0	2
Sodium	maa	ASTM D5185m		1	4	0
Potassium	maa	ASTM D5185m	>20	0	0	2
Water	%	ASTM D6304	>0.05	0.208	0.010	0.006
ppm Water	ppm	ASTM D6304	>500	▲ 2080	107.2	63.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4um		ASTM D7647		1854	1877	2756
Particles >6um		ASTM D7647	>1300	579	571	837
Particles >14um		ASTM D7647	>80	63	36	17
Particles >21um		ASTM D7647	>20	15	8	2
Particles >38um		ASTM D7647	>4	0	2	0
Particles >71um		ASTM D7647	>3	0	- 1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/13	18/16/12	19/17/11
		mothed	limit/baca	ourroot	historyd	history
PLUID DEGRADA		method	innivbase	current	history	historyz



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	🔺 HAZY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	46.1	46.0	46.9
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						



Bottom



Contact/Location: Service Manager - UNLWHI