


PROBLEM SUMMARY

KAESER AIRCENTER SK 15 4481073 (S/N 2587)

Compressor

KAESER SIGMA (OEM) S-460 (--- LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS ABNORMAL Sample Status ABNORMAL ABNORMAL Particles >6µm ASTM D7647 >1300 5989 **4094** ▲ 1899 Particles >14µm ASTM D7647 >80 561 **1**87 Particles >21µm ASTM D7647 >20 212 51 **6**6 Particles >38µm ASTM D7647 >4 **1**7 3 **6 Oil Cleanliness** ISO 4406 (c) >--/17/13 🔺 22/20/16 🔺 19/15 **1**8/15


Customer Id: CESWAS Sample No.: KCPA004237 Lab Number: 05903789 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

25 Feb 2021 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

23 Sep 2019 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

view repor



15 Oct 2018 Diag: Jonathan Hester

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Machine Id KAESER AIRCENTER SK 15 4481073 (S/N 2587) Component

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- LTR)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA004237	KCP35440	KCP22613
Sample Date		Client Info		30 Jun 2023	25 Feb 2021	23 Sep 2019
Machine Age	hrs	Client Info		48200	37583	31256
Oil Age	hrs	Client Info		0	6017	0
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m		0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m		۰ <1	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		2	5	5
Tin		ASTM D5185m	>10	0	0	0
	ppm		>10		0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	33	20	27
Calcium	ppm	ASTM D5185m	2	<1	0	0
Phosphorus	ppm	ASTM D5185m		1	<1	0
Zinc	ppm	ASTM D5185m		0	6	12
Sulfur	ppm	ASTM D5185m		22905	16015	9671
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	2	15
Sodium	ppm	ASTM D5185m		13	11	12
Potassium	ppm	ASTM D5185m	>20	1	2	1
Water	%	ASTM D6304	>0.05	0.020	0.010	0.016
ppm Water	ppm	ASTM D6304		207.1	107.5	166.1
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		23250	12033	7081
Particles >6µm		ASTM D7647	>1300	<u> </u>	4 094	1 899
Particles >14μm		ASTM D7647		6 1	A 221	1 87
Particles >21µm		ASTM D7647		<u> </u>	<u> </u>	<u>▲</u> 66
Particles >38µm		ASTM D7647	>4	1 7	3	<u>▲</u> 6
Particles >71µm		ASTM D7647		2	0	<u> </u>
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	▲ 19/15	<u> </u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.32	0.346	0.293
			<u> </u>			

Acid Number (AN) Report Id: CESWAS [WUSCAR] 05903789 (Generated: 07/24/2023 14:08:20) Rev: 1

Contact/Location: SERVICE MANAGER ? - CESWAS



OIL ANALYSIS REPORT





Bottom

