




# PROBLEM SUMMARY

Sample Rating Trend




**WATER**



Machine Id  
**KAESER AIRCENTER SK 15 4488634 (S/N 2619)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) S-460 (--- LTR)**

## COMPONENT CONDITION SUMMARY

▲ Water



## RECOMMENDATION

The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	NORMAL	NORMAL
Water	%	ASTM D6304	>0.05	▲ <b>0.265</b>	0.017	0.010
ppm Water	ppm	ASTM D6304	>500	▲ <b>2650</b>	173.2	106.7
White Metal	scalar	*Visual	NONE	▲ <b>HEAVY</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ <b>HAZY</b>	NORML	NORML

Customer Id: CESWAS  
 Sample No.: KCPA004243  
 Lab Number: 05903795  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Angela Borella +1 800-237-1369  
[angela.borella@wearcheckusa.com](mailto:angela.borella@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

### 29 Jul 2022 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 25 Feb 2021 Diag: Angela Borella

NORMAL



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 23 Sep 2019 Diag: Jonathan Hester

DIRT




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id  
**KAESER AIRCENTER SK 15 4488634 (S/N 2619)**  
Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) S-460 (--- LTR)**



**DIAGNOSIS**

**Recommendation**

The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

**Wear**

High concentration of visible metal present. All component wear rates are normal.

**Contamination**

There is a light concentration of water present in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

**SAMPLE INFORMATION**

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCPA004243</b>	KCP48352	KCP34950
Sample Date	Client Info		<b>30 Jun 2023</b>	29 Jul 2022	25 Feb 2021
Machine Age	hrs	Client Info	<b>48253</b>	44117	37804
Oil Age	hrs	Client Info	<b>0</b>	6313	6185
Oil Changed	Client Info		<b>N/A</b>	Changed	Changed
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

**WEAR METALS**

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>&lt;1</b>	0	0
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>2</b>	7	7
Tin	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Antimony	ppm	ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

**ADDITIVES**

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m 90	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185m 90	<b>43</b>	13	18
Calcium	ppm	ASTM D5185m 2	<b>1</b>	0	0
Phosphorus	ppm	ASTM D5185m	<b>1</b>	4	0
Zinc	ppm	ASTM D5185m	<b>0</b>	7	2
Sulfur	ppm	ASTM D5185m	<b>23171</b>	16581	15668

**CONTAMINANTS**

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>0</b>	0	4
Sodium	ppm	ASTM D5185m	<b>15</b>	8	11
Potassium	ppm	ASTM D5185m >20	<b>1</b>	0	1
Water	%	ASTM D6304 >0.05	<b>▲ 0.265</b>	0.017	0.010
ppm Water	ppm	ASTM D6304 >500	<b>▲ 2650</b>	173.2	106.7




**FLUID CLEANLINESS**

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>---</b>	916	3554
Particles >6µm	ASTM D7647 >1300		<b>---</b>	314	992
Particles >14µm	ASTM D7647 >80		<b>---</b>	30	68
Particles >21µm	ASTM D7647 >20		<b>---</b>	4	17
Particles >38µm	ASTM D7647 >4		<b>---</b>	1	0
Particles >71µm	ASTM D7647 >3		<b>---</b>	0	0
Oil Cleanliness	ISO 4406 (c) >--/17/13		<b>---</b>	17/15/12	17/13

**FLUID DEGRADATION**

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.36</b>	0.28	0.339


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	▲ <b>HEAVY</b>	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	LIGHT
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Appearance	scalar	*Visual	NORML	▲ <b>HAZY</b>	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML
Emulsified Water	scalar	*Visual	>0.05	<b>0.2%</b>	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	<b>44.3</b>	44.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA004243  
**Lab Number** : 05903795  
**Unique Number** : 10565151  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**C & E SERVICES INC - WATERGATE CENTRAL PLANT**  
 2500 VIRGINIA AVE NW  
 WASHINGTON, DC  
 US 20037  
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: