




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
RIG 879
 Machine Id
R879-P-02-NKL
 Component
Pump
 Fluid
GEAR OIL ISO 320 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2	
Sample Number	Client Info	KL0012131	KL0012129	KL0012133	
Sample Date	Client Info	19 Jul 2023	17 Jul 2023	16 Jul 2023	
Machine Age	days	Client Info	45126	45124	45123
Oil Age	days	Client Info	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A	
Sample Status		ABNORMAL	---	---	

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >500	23	▲ 421	▲ 400
Chromium ppm	ASTM D5185m >7	0	▲ 4	▲ 4
Nickel ppm	ASTM D5185m	0	<1	<1
Titanium ppm	ASTM D5185m	<1	2	2
Silver ppm	ASTM D5185m	0	0	0
Aluminum ppm	ASTM D5185m >25	1	▲ 41	▲ 40
Lead ppm	ASTM D5185m >35	0	0	0
Copper ppm	ASTM D5185m >50	1	17	16
Tin ppm	ASTM D5185m >5	0	<1	<1
Vanadium ppm	ASTM D5185m	<1	<1	<1
Cadmium ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m 50	14	23	20
Barium ppm	ASTM D5185m 15	0	26	24
Molybdenum ppm	ASTM D5185m 15	<1	4	4
Manganese ppm	ASTM D5185m	<1	3	3
Magnesium ppm	ASTM D5185m 50	2	43	42
Calcium ppm	ASTM D5185m 50	16	▲ 194	▲ 183
Phosphorus ppm	ASTM D5185m 350	184	174	175
Zinc ppm	ASTM D5185m 100	13	116	117
Sulfur ppm	ASTM D5185m 12500	10423	11151	11299

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >50	14	● 172	● 162
Sodium ppm	ASTM D5185m	106	1698	1591
Potassium ppm	ASTM D5185m >20	0	22	21

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ 234889	---	---
Particles >6µm	ASTM D7647 >5000	▲ 75606	---	---
Particles >14µm	ASTM D7647 >640	▲ 1192	---	---
Particles >21µm	ASTM D7647 >160	▲ 179	---	---
Particles >38µm	ASTM D7647 >40	3	---	---
Particles >71µm	ASTM D7647 >10	0	---	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 25/23/17	---	---


FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045 0.85	0.51	0.41	0.41




OIL ANALYSIS REPORT


▲ Particle Trend




▲ Particle Trend



Acid Number




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ MILKY	▲ MILKY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	▲ 0.2%	▲ 0.2%
Free Water	scalar	*Visual	NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 320	339	351	349

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : KL0012131 Received : 21 Jul 2023
 Lab Number : 05904314 Diagnosed : 24 Jul 2023
 Unique Number : 10565670 Diagnostician : Doug Bogart
 Test Package : MOB 2 (Additional Tests: PrtCount)

PATTERSON - UTI DRILLING
 9915 WEST INDUSTRIAL
 MIDLAND, TX
 US 79706

Contact: MICHEAL EASTMAN
 micheal.eastman@patenergy.com
 T: (325)716-8686
 F: (432)561-9388

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)