




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**RIG 879**  
 Machine Id  
**R879-P-01**

Component  
**Pump Drive**  
 Fluid  
**BRENTAG COASTAL CHEMICAL HBC GEAR OIL 320 (--- GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KL0011973</b>	KL0011976	KL0011980
Sample Date	Client Info		<b>13 Jul 2023</b>	11 Jul 2023	03 Jul 2023
Machine Age	days	Client Info	<b>45120</b>	45118	45110
Oil Age	days	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	SEVERE

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	<b>69</b>	76	56
Chromium	ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m >10	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >20	<b>7</b>	8	6
Lead	ppm	ASTM D5185m	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >35	<b>3</b>	3	3
Tin	ppm	ASTM D5185m >4	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>5</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>11</b>	11	10
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>11</b>	13	10
Calcium	ppm	ASTM D5185m	<b>230</b>	244	218
Phosphorus	ppm	ASTM D5185m	<b>48</b>	53	41
Zinc	ppm	ASTM D5185m	<b>32</b>	29	27
Sulfur	ppm	ASTM D5185m	<b>10299</b>	10608	8970

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	<b>38</b>	40	33
Sodium	ppm	ASTM D5185m	<b>245</b>	265	197
Potassium	ppm	ASTM D5185m >20	<b>1</b>	6	4

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>▲ 306528</b>	214865	196146
Particles >6µm	ASTM D7647	>5000	<b>▲ 158543</b>	▲ 133002	■ 61579
Particles >14µm	ASTM D7647	>640	<b>▲ 4638</b>	▲ 5463	138
Particles >21µm	ASTM D7647	>160	<b>▲ 819</b>	▲ 754	14
Particles >38µm	ASTM D7647	>40	<b>25</b>	6	0
Particles >71µm	ASTM D7647	>10	<b>3</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>▲ 25/24/19</b>	▲ 24/20	■ 23/14


## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.17</b>	0.08	0.12




# OIL ANALYSIS REPORT


### ▲ Particle Trend




### ▲ Particle Trend



### Acid Number




### Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 310	315	313	316

### SAMPLE IMAGES




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KL0011973 **Received** : 21 Jul 2023  
**Lab Number** : 05904315 **Diagnosed** : 24 Jul 2023  
**Unique Number** : 10565671 **Diagnostician** : Doug Bogart  
**Test Package** : MOB 2 ( Additional Tests: PrtCount )

**PATTERSON - UTI DRILLING**  
 9915 WEST INDUSTRIAL  
 MIDLAND, TX  
 US 79706

Contact: MICHEAL EASTMAN  
 micheal.eastman@patenergy.com  
 T: (325)716-8686  
 F: (432)561-9388

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)