




OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
RIG 879
 Machine Id
R879-P-02-NKL
 Component
Pump
 Fluid
GEAR OIL ISO 320 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you check all areas where dirt can enter the system. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

Wear

All component wear rates are normal.

Contamination

Appearance is milky. There is a high concentration of water present in the oil. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KL0011972	KL0011975	KL0011986
Sample Date	Client Info		13 Jul 2023	11 Jul 2023	07 Jul 2023
Machine Age	days	Client Info	45120	45118	45114
Oil Age	days	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	235	107	83
Chromium	ppm	ASTM D5185m >7	2	1	<1
Nickel	ppm	ASTM D5185m	<1	<1	<1
Titanium	ppm	ASTM D5185m	2	1	1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	▲ 46	▲ 40	▲ 37
Lead	ppm	ASTM D5185m >35	0	<1	0
Copper	ppm	ASTM D5185m >50	15	9	9
Tin	ppm	ASTM D5185m >5	1	1	<1
Vanadium	ppm	ASTM D5185m	<1	<1	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 50	19	13	3
Barium	ppm	ASTM D5185m 15	24	10	25
Molybdenum	ppm	ASTM D5185m 15	5	4	4
Manganese	ppm	ASTM D5185m	2	1	1
Magnesium	ppm	ASTM D5185m 50	47	36	32
Calcium	ppm	ASTM D5185m 50	211	168	155
Phosphorus	ppm	ASTM D5185m 350	171	151	160
Zinc	ppm	ASTM D5185m 100	123	103	102
Sulfur	ppm	ASTM D5185m 12500	11363	11258	11353

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	▲ 168	▲ 129	▲ 137
Sodium	ppm	ASTM D5185m	1924	1699	1772
Potassium	ppm	ASTM D5185m >20	25	22	21
Water	%	ASTM D6304	● 2.80	● 3.50	● 1.76
ppm Water	ppm	ASTM D6304 >.1	● 28000	● 35000	● 17600

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	---	---	---
Particles >6µm	ASTM D7647	>5000	---	---	---
Particles >14µm	ASTM D7647	>640	---	---	---
Particles >21µm	ASTM D7647	>160	---	---	---
Particles >38µm	ASTM D7647	>40	---	---	---
Particles >71µm	ASTM D7647	>10	---	---	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	---	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.85	0.43	0.43	0.17




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	LIGHT
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	▲ MILKY	▲ MILKY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	● 0.2%	● 0.2%	● 0.2%
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 320	358	364	349

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0011972 **Received** : 21 Jul 2023
Lab Number : 05904318 **Diagnosed** : 26 Jul 2023
Unique Number : 10565674 **Diagnostician** : Don Baldrige
Test Package : MOB 2 (Additional Tests: KF, PrtCount)

PATTERSON - UTI DRILLING
 9915 WEST INDUSTRIAL
 MIDLAND, TX
 US 79706
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
 F: (432)561-9388