


## **PROBLEM SUMMARY**

# KAESER ASD40 8077875 (S/N 1408)

Compressor

## KAESER SIGMA (OEM) S-460 (--- GAL)

## COMPONENT CONDITION SUMMARY



### RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS					
Sample Status		ABNORMAL	NORMAL	NORMAL	
Particles >6µm	ASTM D7647 >	1300 🔺 6090	514	652	
Particles >14µm	ASTM D7647 >	80 🔺 133	34	14	
Oil Cleanliness	ISO 4406 (c) >	/17/13 🔺 21/20/14	17/16/12	19/17/11	


Customer Id: WINKEW Sample No.: KC05904386 Lab Number: 05904386 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



RECOMMENDED ACTIONS					
Action	Status	Date	Done By	Description	
Change Filter			?	We recommend you service the filters on this component.	

## HISTORICAL DIAGNOSIS

#### NORMAL



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 09 Sep 2022 Diag: Angela Borella

16 Jan 2023 Diag: Doug Bogart

NORMAL



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





## **OIL ANALYSIS REPORT**

# KAESER ASD40 8077875 (S/N 1408)

**Compressor** Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

## Wear


All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05904386	KC87091	KC95836
Sample Date		Client Info		18 Jul 2023	16 Jan 2023	09 Sep 2022
Machine Age	hrs	Client Info		5143	3420	2043
Oil Age	hrs	Client Info		0	1197	2043
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		15	4	9
Tin	ppm	ASTM D5185m		0	0	<1
Vanadium	ppm	ASTM D5185m	-	<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	nnm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	00	0	24	0
	ppm		90	0	0	0
Molybdenum	ppm	ASTM D5185m			0	
Manganese	ppm	ASTM D5185m	90	<1	47	<1 21
Magnesium	ppm	ASTM D5185m		1 0		0
Calcium	ppm	ASTM D5185m	2	-	1	
Phosphorus	ppm	ASTM D5185m		<1	9	1
Zinc	ppm	ASTM D5185m		0	10	21
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	1	<1
Sodium	ppm	ASTM D5185m		2	16	7
Potassium	ppm	ASTM D5185m		0	7	5
Water	%	ASTM D6304	>0.05	0.005	0.012	0.012
ppm Water	ppm	ASTM D6304	>500	51.3	125.6	121.2
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		13115	1110	4517
Particles >6µm		ASTM D7647		<u> </u>	514	652
Particles >14µm		ASTM D7647	>80	<u> </u>	34	14
Particles >21µm		ASTM D7647	>20	13	7	2
Particles >38µm		ASTM D7647	>4	0	1	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 21/20/14	17/16/12	19/17/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.35	0.32	0.32



## **OIL ANALYSIS REPORT**









			11 11 11			
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.5	44.6	45.1
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Color						





Bottom



\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: SERVICE MANAGER ? - WINKEW