

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO

#### Machine Id

# KAESER ASD 25 7951338 (S/N 1141)

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status			ATTENTION	ATTENTION						
Particles >6μm	ASTM D7647	>1300	<b>1907</b>	<u></u> 1906						
Particles >14μm	ASTM D7647	>80	<b>4</b> 90	<u> </u>						
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>20/18/14</b>	A 21/18/14						

Customer Id: CHACAL Sample No.: KCPA002145 Lab Number: 05904387 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

# 12 Aug 2022 Diag: Jonathan Hester

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

T T

Sample Rating Trend

ISO

Machine Id

# KAESER ASD 25 7951338 (S/N 1141)

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Aug2022	Jun2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
	MATION		IIIIIIIIIIIIIII		,	,
Sample Number		Client Info		KCPA002145	KC106237	
Sample Date		Client Info		16 Jun 2023	12 Aug 2022	
Machine Age	hrs	Client Info		816	442	
Oil Obarrad	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A ATTENTION	Changed	
Sample Status				ATTENTION	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	7	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m		<1	<1	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	<1	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		5	7	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m	500	428	242	
Zinc	ppm	ASTM D5185m		76	11	
Sulfur	ppm	ASTM D5185m		4418	7191	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	
Sodium	ppm	ASTM D5185m		3	<1	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.004	0.006	
ppm Water	ppm	ASTM D6304	>500	46.3	67.6	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		7413	15949	
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u>1906</u>	
Particles >14μm		ASTM D7647	>80	<u> </u>	<u>118</u>	
Particles >21µm		ASTM D7647	>20	20	<b>△</b> 35	
Particles >38µm		ASTM D7647	>4	1	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/18/14</b>	<u>^</u> 21/18/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	та КОЦ/а	ASTM D8045		1 34	0.78	

Acid Number (AN)

mg KOH/g ASTM D8045 1.5


1.34

0.78



# **OIL ANALYSIS REPORT**





Certificate L2367

**Unique Number** 

: 10565743

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician : Angela Borella

US 94515

Contact:

T: F: