


# PROBLEM SUMMARY

Sample Rating Trend



ISO




Machine Id  
**4176972 (S/N 1033)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ATTENTION	---
Particles >6µm	ASTM D7647	>1300	▲ <b>11368</b>	▲ 1724	---
Particles >14µm	ASTM D7647	>80	▲ <b>1012</b>	▲ 140	---
Particles >21µm	ASTM D7647	>20	▲ <b>253</b>	▲ 23	---
Particles >38µm	ASTM D7647	>4	▲ <b>10</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>22/21/17</b>	▲ 18/14	---

Customer Id: HALNORCA  
Sample No.: KCPA005346  
Lab Number: 05904396  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Angela Borella +1 800-237-1369  
[angela.borella@wearcheckusa.com](mailto:angela.borella@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 21 Mar 2022 Diag: Don Baldrige

ISO




Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**4176972 (S/N 1033)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

**DIAGNOSIS**

▲ **Recommendation**

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

**Wear**

All component wear rates are normal.

▲ **Contamination**

There is a high amount of particulates present in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

**SAMPLE INFORMATION** method limit/base current history1 history2

Sample Number	Client Info	<b>KCPA005346</b>	KCP41035	---
Sample Date	Client Info	<b>11 Jul 2023</b>	21 Mar 2022	---
Machine Age	hrs	Client Info	<b>13353</b>	11901
Oil Age	hrs	Client Info	<b>0</b>	1723
Oil Changed	Client Info	<b>N/A</b>	Changed	---
Sample Status		<b>ABNORMAL</b>	ATTENTION	---

**WEAR METALS** method limit/base current history1 history2

Iron	ppm	ASTM D5185m	>50	<b>0</b>	0	---
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	---
Nickel	ppm	ASTM D5185m	>3	<b>0</b>	0	---
Titanium	ppm	ASTM D5185m	>3	<b>&lt;1</b>	0	---
Silver	ppm	ASTM D5185m	>2	<b>0</b>	<1	---
Aluminum	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	---
Lead	ppm	ASTM D5185m	>10	<b>0</b>	<1	---
Copper	ppm	ASTM D5185m	>50	<b>1</b>	2	---
Tin	ppm	ASTM D5185m	>10	<b>0</b>	<1	---
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	---

**ADDITIVES** method limit/base current history1 history2

Boron	ppm	ASTM D5185m	0	<b>0</b>	0	---
Barium	ppm	ASTM D5185m	90	<b>17</b>	0	---
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	0	---
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Magnesium	ppm	ASTM D5185m	100	<b>66</b>	61	---
Calcium	ppm	ASTM D5185m	0	<b>&lt;1</b>	0	---
Phosphorus	ppm	ASTM D5185m	0	<b>6</b>	11	---
Zinc	ppm	ASTM D5185m	0	<b>4</b>	1	---
Sulfur	ppm	ASTM D5185m	23500	<b>23531</b>	19543	---

**CONTAMINANTS** method limit/base current history1 history2

Silicon	ppm	ASTM D5185m	>25	<b>6</b>	9	---
Sodium	ppm	ASTM D5185m		<b>25</b>	19	---
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	4	---
Water	%	ASTM D6304	>0.05	<b>0.026</b>	0.011	---
ppm Water	ppm	ASTM D6304	>500	<b>263.8</b>	119.9	---






**FLUID CLEANLINESS** method limit/base current history1 history2

Particles >4µm	ASTM D7647			<b>28554</b>	5507	---
Particles >6µm	ASTM D7647	>1300		▲ <b>11368</b>	▲ 1724	---
Particles >14µm	ASTM D7647	>80		▲ <b>1012</b>	▲ 140	---
Particles >21µm	ASTM D7647	>20		▲ <b>253</b>	▲ 23	---
Particles >38µm	ASTM D7647	>4		▲ <b>10</b>	0	---
Particles >71µm	ASTM D7647	>3		<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>--/17/13		▲ <b>22/21/17</b>	▲ 18/14	---

**FLUID DEGRADATION** method limit/base current history1 history2

Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	<b>0.38</b>	0.38	---
------------------	----------	------------	-----	-------------	------	-----


# OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	46.3	46.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA005346 **Received** : 21 Jul 2023  
**Lab Number** : 05904396 **Diagnosed** : 25 Jul 2023  
**Unique Number** : 10565752 **Diagnostician** : Angela Borella  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**HALLSTEN**  
 6944 34TH ST  
 NORTH HIGHLANDS, CA  
 US 95660  
 Contact: R. WRIGHT  
 rwright@hallsten.com  
 T:  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)