



# **PROBLEM SUMMARY**



### Machine Id 7549894 (S/N 1130) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

## COMPONENT CONDITION SUMMARY



### RECOMMENDATION

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS											
Sample Status				ABNORMAL	ATTENTION						
Water	%	ASTM D6304	>0.05	<b>A</b> 0.301	0.016						
ppm Water	ppm	ASTM D6304	>500	<b>A</b> 3010	164.8						

Customer Id: NPSSPA Sample No.: KCPA005032 Lab Number: 05904397 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com There are no recommended actions for this sample.

#### HISTORICAL DIAGNOSIS

### 03 May 2022 Diag: Angela Borella



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





## **OIL ANALYSIS REPORT**

### Sample Rating Trend

WATER

Machine Id 7549894 (S/N 1130) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

### DIAGNOSIS

#### Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

#### Wear

All component wear rates are normal.

#### Contamination

There is a light concentration of water present in the oil.


#### Fluid Condition


The AN level is acceptable for this fluid.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA005032	KCP45015	
Sample Date		Client Info		06 Jul 2023	03 May 2022	
Machine Age	hrs	Client Info		2762	2088	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm		>50	3	2	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m	-	<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	
Barium	ppm	ASTM D5185m	90	11	30	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m	-	<1	<1	
Magnesium	ppm	ASTM D5185m	100	53	66	
Calcium	ppm	ASTM D5185m	0	2	2	
Phosphorus	ppm	ASTM D5185m	0	8	5	
Zinc	ppm	ASTM D5185m		4	0	
Sulfur	ppm	ASTM D5185m	23500	23129	15645	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	16	<1	
Sodium	ppm	ASTM D5185m		9	13	
Potassium	ppm	ASTM D5185m	>20	<1	7	
Water	%	ASTM D6304	>0.05	<b>A</b> 0.301	0.016	
ppm Water	ppm	ASTM D6304	>500	<b>A</b> 3010	164.8	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			9870	
Particles >6µm		ASTM D7647	>1300		<b>▲</b> 1728	
Particles >14µm		ASTM D7647	>80		50	
Particles >21µm		ASTM D7647	>20		10	
Particles >38µm		ASTM D7647	>4		0	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		▲ 20/18/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
			1.0		0.42	
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.48	0.42	




## **OIL ANALYSIS REPORT**











Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Laboratory

Sample No.

Certificate L2367

Lab Number

T:

F: