



PROBLEM SUMMARY


PLUS 10 [1387209] Machine Id ATLAS COPCO All471-984 - APTIV VIENNA

Compressor



COMPONENT CONDITION SUMMARY





RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status				ABNORMAL	ABNORMAL				
Acid Number (AN)	mg KOH/g	ASTM D8045	0.537	2.04	▲ 1.84				
Visc @ 40°C	cSt	ASTM D445	44.56	△ 54.4	A 55.9				

Customer Id: UCAIRCLE Sample No.: UCH05904472 Lab Number: 05904472 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		

HISTORICAL DIAGNOSIS

18 Jul 2022 Diag: Doug Bogart

DEGRADATION



The oil is near the end of it's useful service life, recommend schedule an oil change. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The oil viscosity is higher than normal. The AN level is at the top-end of the recommended limit.






OIL ANALYSIS REPORT

PLUS 10 [1387209] **ATLAS COPCO Ali471-984 - APTIV VIENNA**

Compressor





DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The oil viscosity is higher than normal. The AN level is at the top-end of the recommended limit.

			Jul2022	Jun 2 023		
SAMPLE INFORM	AATIONI	ام مالم مما	1: ! 		la i a ta mud	hieten O
	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH05904472	UCH05611358	
Sample Date		Client Info		29 Jun 2023	18 Jul 2022	
Machine Age	hrs	Client Info		137694	129135	
Oil Age	hrs	Client Info		8000	7998	
Oil Changed		Client Info		Changed	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>5	0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>15	0	0	
Lead	ppm	ASTM D5185m	>65	<1	0	
Copper	ppm	ASTM D5185m	>65	<1	<1	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0.1	0	<1	
Barium	ppm	ASTM D5185m	0.8	2	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m	0.9	0	0	
Magnesium	ppm	ASTM D5185m	0	<1	<1	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	409	279	<u>^</u> 3	
Zinc	ppm	ASTM D5185m	0	7	0	
Sulfur	ppm	ASTM D5185m	1290	117	^ 0	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	0	0	
Sodium	ppm	ASTM D5185m		0	<1	
Potassium	ppm	ASTM D5185m	>20	<1	1	
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.537	2.04	1.84	
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	
:25:11) Dov: 1				antant/Loostian	· DEDDICK DAE	e licaidoi e



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

: UCH05904472 : 05904472 Unique Number : 10565828 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 21 Jul 2023

Diagnosed : 24 Jul 2023 Diagnostician : Doug Bogart

6500 DAVIS INDUSTRIAL PARKWAY CLEVELAND, OH US 44139

Contact: DERRICK PAES

DPAES@AIRCOMPRESSORS.COM T: (440)349-3900

AIR TECHNOLOGIES INC (CLE)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (440)349-0608

Contact/Location: DERRICK PAES - UCAIRCLE

Report Id: UCAIRCLE [WUSCAR] 05904472 (Generated: 07/24/2023 11:25:12) Rev: 1