




# OIL ANALYSIS REPORT



Machine Id  
**BRCM02BE (S/N GZJ00659)**  
 Component  
**Biogas Engine**  
 Fluid  
**CHEVRON HDAX 6500 LFG GAS ENGINE OIL (--- GAL)**

Sample Rating Trend



**NORMAL**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0760987</b>	WC0761002	WC0760998
Sample Date	Client Info		<b>18 Jul 2023</b>	27 Jun 2023	12 Jun 2023
Machine Age	hrs	Client Info	<b>69322</b>	68978	68636
Oil Age	hrs	Client Info	<b>82</b>	91	546
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	SEVERE	SEVERE

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<b>1</b>	4	4
Chromium	ppm	ASTM D5185m	>4	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m	>2	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>6	<b>1</b>	2	2
Lead	ppm	ASTM D5185m	>9	<b>2</b>	4	3
Copper	ppm	ASTM D5185m	>6	<b>&lt;1</b>	2	<1
Tin	ppm	ASTM D5185m	>4	<b>2</b>	5	5
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>6</b>	19	18
Barium	ppm	ASTM D5185m		<b>2</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>7</b>	12	12
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>28</b>	56	67
Calcium	ppm	ASTM D5185m		<b>1756</b>	1788	1879
Phosphorus	ppm	ASTM D5185m		<b>281</b>	325	366
Zinc	ppm	ASTM D5185m		<b>346</b>	414	451
Sulfur	ppm	ASTM D5185m		<b>1806</b>	2328	2820

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	<b>64</b>	216	214
Sodium	ppm	ASTM D5185m		<b>0</b>	0	1
Potassium	ppm	ASTM D5185m	>20	<b>1</b>	2	2

## INFRA-RED




	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	<b>5.4</b>	6.9	6.3
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>15.5</b>	19.8	20.1

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>8.5</b>	13.6	14.9
Acid Number (AN)	mg KOH/g	ASTM D8045	1.2	<b>0.60</b>	1.55	1.31
Base Number (BN)	mg KOH/g	ASTM D2896	4.5	<b>5.61</b>	4.93	4.30











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.7	12.9	13.1

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0760987 **Received** : 21 Jul 2023  
**Lab Number** : 05904510 **Diagnosed** : 25 Jul 2023  
**Unique Number** : 10565866 **Diagnostician** : Angela Borella  
**Test Package** : MOB 2

**EDL NA Recips-Brown County**  
 BROWN COUNTY POWER STATION, 9427 BEYERS RD  
 GEORGETOWN, OH  
 US 45121  
 Contact: MITCHELL BUTLER  
 Mitchell.Butler@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)