


PROBLEM SUMMARY

Area
Paper Side
 Machine Id
Paper Machine 1 Main Bowser
 Component
Bearing Lube
 Fluid
SHELL PM S2 M 220 (3500 GAL)

Sample Rating Trend




WEAR




COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Non-ferrous Metals



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Copper	ppm	ASTM D5185m >17	▲ 79	▲ 93	▲ 64
Particles >4µm		ASTM D7647 >10000	▲ 106706	▲ 144181	▲ 146940
Particles >6µm		ASTM D7647 >2500	▲ 13072	▲ 36621	▲ 26367
Particles >14µm		ASTM D7647 >160	▲ 193	▲ 684	▲ 518
Oil Cleanliness		ISO 4406 (c) >20/18/14	▲ 24/21/15	▲ 24/22/17	▲ 24/22/16

Customer Id: MCKPOR
 Sample No.: PE0000990
 Lab Number: 05904874
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

28 Jun 2023 Diag: Jonathan Hester

WEAR



We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



08 Jun 2023 Diag: Jonathan Hester

WEAR



We recommend you service the filters on this component. Resample at the next service interval to monitor. Please note that this is a corrected copy for laboratory data updates. The copper level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



03 Apr 2023 Diag: Angela Borella

WEAR




No corrective action is recommended at this time. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
Paper Side
 Machine Id
Paper Machine 1 Main Bowser
 Component
Bearing Lube
 Fluid
SHELL PM S2 M 220 (3500 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PE0000990	PE0000984	PE0000983
Sample Date	Client Info	18 Jul 2023	28 Jun 2023	08 Jun 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184	14	16	19	
Iron	ppm	ASTM D5185m >120	3	6	4
Chromium	ppm	ASTM D5185m >5	<1	<1	<1
Nickel	ppm	ASTM D5185m >20	<1	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	<1
Aluminum	ppm	ASTM D5185m >4	0	0	0
Lead	ppm	ASTM D5185m >30	7	10	6
Copper	ppm	ASTM D5185m >17	▲ 79	▲ 93	▲ 64
Tin	ppm	ASTM D5185m >10	4	5	2
Vanadium	ppm	ASTM D5185m	0	<1	0
Cadmium	ppm	ASTM D5185m	0	<1	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	2	0	0
Molybdenum	ppm	ASTM D5185m	<1	<1	2
Manganese	ppm	ASTM D5185m	0	0	0
Magnesium	ppm	ASTM D5185m	3	4	1
Calcium	ppm	ASTM D5185m	91	58	134
Phosphorus	ppm	ASTM D5185m	790	647	657
Zinc	ppm	ASTM D5185m	1075	905	927
Sulfur	ppm	ASTM D5185m	6089	6210	6177

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	2	2	2
Sodium	ppm	ASTM D5185m	0	<1	<1
Potassium	ppm	ASTM D5185m >20	<1	2	0


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 106706	▲ 144181	▲ 146940
Particles >6µm	ASTM D7647 >2500	▲ 13072	▲ 36621	▲ 26367
Particles >14µm	ASTM D7647 >160	▲ 193	▲ 684	▲ 518
Particles >21µm	ASTM D7647 >40	29	▲ 117	▲ 96
Particles >38µm	ASTM D7647 >10	1	2	5
Particles >71µm	ASTM D7647 >3	0	0	1
Oil Cleanliness	ISO 4406 (c) >20/18/14	▲ 24/21/15	▲ 24/22/17	▲ 24/22/16


FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.85	0.91	0.77


▲ Particle Trend




● PQ




▲ Non-ferrous Metals



Acid Number



Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	LIGHT	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	220	227	233	226

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color



no image


Bottom




no image

GRAPHS


Ferrous Alloys




▲ Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PE0000990 **Received** : 21 Jul 2023
Lab Number : 05904874 **Diagnosed** : 24 Jul 2023
Unique Number : 10566230 **Diagnostician** : Doug Bogart
Test Package : PLANT (Additional Tests: ICP, KV40, PQ, PrtCount, SCREEN)

MCKINLEY PAPER COMPANY
 1902 MARINE DR
 PORT ANGELES, WA
 US 98363

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)
 Contact: CHAD GALLAUHER
 chad.gallauher@biopappel.com
 T: (360)457-4474
 F: