


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id KAESER BSD 60 4127445 (S/N 1003)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb2021 /	Aug2021 Feb2022 Jun20	22 Oct2022 Jan2023 Apr2023	3 Jul2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121487	KC107728	KC108108
Sample Date		Client Info		17 Jul 2023	17 Apr 2023	16 Jan 2023
Machine Age	hrs	Client Info		45298	44323	43137
Oil Age	hrs	Client Info		0	2500	2000
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	5	<1	2
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	41	66
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	1	62	70
Calcium	ppm	ASTM D5185m	2	0	1	2
Phosphorus	ppm	ASTM D5185m		0	3	4
Zinc	ppm	ASTM D5185m		0	0	4
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	2
Sodium	ppm	ASTM D5185m		2	20	25
Potassium	ppm	ASTM D5185m	>20	0	2	4
Water	%	ASTM D6304	>0.05	0.006	0.020	0.016
ppm Water	ppm	ASTM D6304	>500	60.0	205.0	165.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		915	476	802
Particles >6µm		ASTM D7647	>1300	242	126	186
Particles >14µm		ASTM D7647	>80	18	14	12
Particles >21µm		ASTM D7647	>20	5	5	3
Particles >38µm		ASTM D7647	>4	1	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/11	16/14/11	17/15/11
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.38	0.42	0.45



OIL ANALYSIS REPORT







Certificate L2367

Lab Number **Unique Number** Test Package

: 05904932

: 10566288 : IND 2

Diagnosed : 25 Jul 2023

Diagnostician : Angela Borella HIGHLAND HEIGHTS, OH US 44143

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: