




PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
342 - COMBINED CONDENSATE
 Component
Pump
 Fluid
MOBIL SHC 626 (1 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. Analytical Ferrography: Results are normal with typical amounts of ferrous rubbing wear and contamination present.

PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	SEVERE	---
Particles >4µm	ASTM D7647 >5000	▲ 7709	● 131992	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 20/15/10	● 24/22/16	---

Customer Id: GRAMAC
 Sample No.: WC0824320
 Lab Number: 05904970
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:

Aaron Black +1
aaron.black@wearcheck.com

To change component or sample information:

Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

ISO



24 Mar 2023 Diag: Aaron Black

Resample in 30-45 days to monitor this situation. Analytical Ferrography: Results show an abnormal amount of ferrous rubbing wear with no apparent source; viscosity is within tolerance and no degradation byproducts are evident. This suggests that excessive wear may be a result of a mechanical problem such as soft foot or misalignment. Suggest checking/verifying system with vibration equipment (if possible) and correcting if possible. Another possibility is viscosity that is too low for ambient temperatures; suggesting checking manufacturers viscosity requirements for ambient temperature and ensuring they are being met. Wear particle analysis indicates that the ferrous rubbing particles are abnormal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
342 - COMBINED CONDENSATE

Component
Pump
Fluid
MOBIL SHC 626 (1 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. Analytical Ferrography: Results are normal with typical amounts of ferrous rubbing wear and contamination present.

Wear

All component wear rates are normal. The analytical ferrographic results are normal indicating no abnormal wear in the system.

Contaminants

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

Oil Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0824320	WC0783647	---
Sample Date	Client Info			19 Jul 2023	24 Mar 2023	---
Machine Age	mths	Client Info		0	0	---
Oil Age	mths	Client Info		4	0	---
Oil Changed	Client Info			Not Chngd	N/A	---
Sample Status				ATTENTION	SEVERE	---

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		9	19	---
Iron	ppm	ASTM D5185m	>90	8	18	---
Chromium	ppm	ASTM D5185m	>5	0	0	---
Nickel	ppm	ASTM D5185m	>5	<1	0	---
Titanium	ppm	ASTM D5185m	>3	0	0	---
Silver	ppm	ASTM D5185m	>3	0	0	---
Aluminum	ppm	ASTM D5185m	>7	0	<1	---
Lead	ppm	ASTM D5185m	>12	0	0	---
Copper	ppm	ASTM D5185m	>30	0	0	---
Tin	ppm	ASTM D5185m	>9	0	0	---
Vanadium	ppm	ASTM D5185m		0	0	---
Cadmium	ppm	ASTM D5185m		0	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	---
Barium	ppm	ASTM D5185m		0	0	---
Molybdenum	ppm	ASTM D5185m		0	0	---
Manganese	ppm	ASTM D5185m		<1	1	---
Magnesium	ppm	ASTM D5185m		0	0	---
Calcium	ppm	ASTM D5185m		0	0	---
Phosphorus	ppm	ASTM D5185m		436	421	---
Zinc	ppm	ASTM D5185m		0	0	---
Sulfur	ppm	ASTM D5185m		0	0	---






CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	1	2	---
Sodium	ppm	ASTM D5185m		<1	<1	---
Potassium	ppm	ASTM D5185m	>20	0	<1	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	▲ 7709	131992	---
Particles >6µm		ASTM D7647	>1300	301	31749	---
Particles >14µm		ASTM D7647	>160	6	487	---
Particles >21µm		ASTM D7647	>40	2	69	---
Particles >38µm		ASTM D7647	>10	0	5	---
Particles >71µm		ASTM D7647	>3	0	0	---
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ 20/15/10	24/22/16	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.65	0.50	---




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	VLITE	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	NEG	NEG	---	---
Free Water	scalar	*Visual	NEG	NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	69.9	66.2	70.2	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS







Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0824320 **Received** : 21 Jul 2023
Lab Number : 05904970 **Diagnosed** : 03 Aug 2023
Unique Number : 10566326 **Diagnostician** : Aaron Black
Test Package : PLANT (Additional Tests: A-FERR)

GRAPHIC PACKAGING INTERNATIONAL
 100 GRAPHIC PACKAGING INTERNATIONAL
 MACON, GA
 US 31206
 Contact: DARYL SPRINGER
 daryl.springer@graphicpkg.com
 T: (478)784-3677
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FERROGRAPHY REPORT

Machine Id
342 - COMBINED CONDENSATE
 Component
Pump
 Fluid
MOBIL SHC 626 (1 GAL)



FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	*ASTM D7684		■ 2	▲ 5	
Ferrous Sliding	Scale 0-10	*ASTM D7684				
Ferrous Cutting	Scale 0-10	*ASTM D7684				
Ferrous Rolling	Scale 0-10	*ASTM D7684				
Ferrous Break-in	Scale 0-10	*ASTM D7684				
Ferrous Spheres	Scale 0-10	*ASTM D7684				
Ferrous Black Oxides	Scale 0-10	*ASTM D7684				
Ferrous Red Oxides	Scale 0-10	*ASTM D7684				
Ferrous Corrosive	Scale 0-10	*ASTM D7684				
Ferrous Other	Scale 0-10	*ASTM D7684				
Nonferrous Rubbing	Scale 0-10	*ASTM D7684				
Nonferrous Sliding	Scale 0-10	*ASTM D7684				
Nonferrous Cutting	Scale 0-10	*ASTM D7684				
Nonferrous Rolling	Scale 0-10	*ASTM D7684				
Nonferrous Other	Scale 0-10	*ASTM D7684				
Carbonaceous Material	Scale 0-10	*ASTM D7684				
Lubricant Degradation	Scale 0-10	*ASTM D7684				
Sand/Dirt	Scale 0-10	*ASTM D7684				
Fibres	Scale 0-10	*ASTM D7684				
Spheres	Scale 0-10	*ASTM D7684				
Other	Scale 0-10	*ASTM D7684		■ 2	▲ 3	

WEAR

All component wear rates are normal.
 The analytical ferrographic results are normal indicating no abnormal wear in the system.

This page left intentionally blank