

FUEL REPORT

Machine Id BLYTHE CHAPEL HILL RD - LIGHT RED Component

Diesel Fuel Fluid NOT GIVEN (--- QTS)

DIAGNOSIS

A Recommendation

Recommedn pre-filtering before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Corrosion


All metal levels are normal indicating no corrosion in the system.

Contaminants

Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

Fuel Condition


Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur value derived by ASTM D5453 method for ULSD validation.





SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC05905081		
Sample Date		Client Info		20 Jul 2023		
Machine Age	hrs	Client Info		0		
Sample Status	1115			ABNORMAL		
-						
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.845		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.0		
Visc @ 40°C	cSt	ASTM D445		2.63		
Pensky-Martens Flash Point	°C	*PMCC Calculated		60		
SULFUR CONTER	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		7		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		166		
5% Distillation Point	°C	ASTM D86		194		
10% Distill Point	°C	ASTM D86		206		
15% Distillation Point	°C	ASTM D86		216		
20% Distill Point	°C	ASTM D86		224		
30% Distill Point	°C	ASTM D86		239		
40% Distill Point	°C	ASTM D86		252		
50% Distill Point	°C	ASTM D86		267		
60% Distill Point	°C	ASTM D86		281		
70% Distill Point	°C	ASTM D86		296		
80% Distill Point	°C	ASTM D86		312		
85% Distillation Point	°C	ASTM D86		320		
90% Distill Point	°C	ASTM D86		330		
95% Distillation Point	°C	ASTM D86		344		
Final Boiling Point	°C	ASTM D86		351		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.7		
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		36.0		
Cetane Index		ASTM D4737	<40.0	47.9		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.008		
ppm Water	ppm	ASTM D6304	<500	82.7		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	3.9		



FUEL REPORT








HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	<1		
Nickel	ppm	ASTM D5185m	<0.1	0		
Lead	ppm	ASTM D5185m	<0.1	0		
Vanadium	ppm	ASTM D5185m	<0.1	<1		
Iron	ppm	ASTM D5185m	<0.1	0		
Calcium	ppm	ASTM D5185m	<0.1	0		
Magnesium	ppm	ASTM D5185m	<0.1	1		
Phosphorus	ppm	ASTM D5185m	<0.1	0		
Zinc	ppm	ASTM D5185m	<0.1	0		




Bottom





Pensky-Martens Flash Point (°C)





Test Package : DF-2 (Additional Tests: Screen) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received

Diagnosed

: 21 Jul 2023

: 02 Aug 2023

Diagnostician : Doug Bogart

: WC05905081

: 05905081

Report Id: COUDUR [WUSCAR] 05905081 (Generated: 08/04/2023 01:00:21) Rev: 1

Laboratory Sample No.

Lab Number

Unique Number : 10566437

Contact/Location: JESSE BROWN - COUDUR

F:

T: (919)285-5408