




# PROBLEM SUMMARY


## Sample Rating Trend



Machine Id  
**TU-1 (S/N 1-25770-1)**  
 Component  
**Agitator Gearbox**  
 Fluid  
**MOBIL MOBILGEAR 630 (2 GAL)**

## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time.  
 Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	NORMAL
Particles >4µm	ASTM D7647 >20000	▲ 43199	▲ 81026	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 23/19/13	▲ 24/19/13	---

Customer Id: AVEMIL  
 Sample No.: WC05905404  
 Lab Number: 05905404  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 16 Feb 2021 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 30 Jan 2019 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 18 Sep 2013 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

ISO



Machine Id  
**TU-1 (S/N 1-25770-1)**  
 Component  
**Agitator Gearbox**  
 Fluid  
**MOBIL MOBILGEAR 630 (2 GAL)**



## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC05905404</b>	WC0507890	WCI2341322
Sample Date	Client Info		<b>23 Jul 2023</b>	16 Feb 2021	30 Jan 2019
Machine Age	mths	Client Info	<b>0</b>	0	0
Oil Age	mths	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >150	<b>13</b>	14	15
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >100	<b>&lt;1</b>	<1	<1
Copper	ppm	ASTM D5185m >50	<b>2</b>	2	2
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Antimony	ppm	ASTM D5185m >5	<b>---</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	2	2
Barium	ppm	ASTM D5185m	<b>4</b>	3	3
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185m	<b>5</b>	4	5
Phosphorus	ppm	ASTM D5185m	<b>198</b>	216	201
Zinc	ppm	ASTM D5185m	<b>29</b>	15	25
Sulfur	ppm	ASTM D5185m	<b>17520</b>	14456	19615

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>2</b>	2	2
Sodium	ppm	ASTM D5185m	<b>0</b>	4	4
Potassium	ppm	ASTM D5185m >20	<b>1</b>	<1	<1

## FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>▲ 43199</b>	▲ 81026	---
Particles >6µm	ASTM D7647	>5000	<b>3402</b>	4606	---
Particles >14µm	ASTM D7647	>640	<b>72</b>	57	---
Particles >21µm	ASTM D7647	>160	<b>14</b>	10	---
Particles >38µm	ASTM D7647	>40	<b>1</b>	0	---
Particles >71µm	ASTM D7647	>10	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>▲ 23/19/13</b>	▲ 24/19/13	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.56</b>	0.543	0.614



# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	212	213

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC05905404 **Received** : 24 Jul 2023  
**Lab Number** : 05905404 **Diagnosed** : 26 Jul 2023  
**Unique Number** : 10566760 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**AVERY DENNISON CHEMICAL DIVISION**  
 171 DRAKETOWN RD  
 MILL HALL, PA  
 US 17751  
 Contact: DONALD EYER  
 DONALD.EYER@AVERYDENNISON.COM  
 T:  
 F: (570)748-1813

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)