




# PROBLEM SUMMARY

Sample Rating Trend



## SEDIMENT



Machine Id  
**T-101**  
 Component  
**Agitator Gearbox**  
 Fluid  
**GEAR OIL ISO 320 (--- GAL)**

### COMPONENT CONDITION SUMMARY

No relevant graphs to display

### RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	NORMAL
Silt	scalar	*Visual	NONE	<b>▲ MODER</b>	NONE	NONE

Customer Id: AVEMIL  
 Sample No.: WC05905410  
 Lab Number: 05905410  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

### 16 Feb 2021 Diag: Wes Davis

ISO



Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) GEAR OIL ISO 320. Please confirm.

NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 30 Jan 2019 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 06 Jan 2017 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

## Sample Rating Trend



## SEDIMENT



Machine Id

**T-101**

Component

**Agitator Gearbox**

Fluid

**GEAR OIL ISO 320 (--- GAL)**

### DIAGNOSIS

#### ▲ Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a moderate amount of visible silt present in the sample.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC05905410</b>	WC0507880	WCI2303618
Sample Date	Client Info		<b>23 Jul 2023</b>	16 Feb 2021	30 Jan 2019
Machine Age	mths	Client Info	<b>0</b>	0	0
Oil Age	mths	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >150	<b>7</b>	8	7
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m >10	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	<1
Silver	ppm	ASTM D5185m	<b>&lt;1</b>	2	<1
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >100	<b>2</b>	2	2
Copper	ppm	ASTM D5185m >50	<b>2</b>	4	5
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	0
Antimony	ppm	ASTM D5185m >5	<b>---</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	<1	<1

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 50	<b>28</b>	33	37
Barium	ppm	ASTM D5185m 15	<b>&lt;1</b>	<1	<1
Molybdenum	ppm	ASTM D5185m 15	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>3</b>	3	3
Magnesium	ppm	ASTM D5185m 50	<b>3</b>	4	4
Calcium	ppm	ASTM D5185m 50	<b>11</b>	12	13
Phosphorus	ppm	ASTM D5185m 350	<b>255</b>	261	231
Zinc	ppm	ASTM D5185m 100	<b>47</b>	38	45
Sulfur	ppm	ASTM D5185m 12500	<b>9356</b>	7516	9680

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>5</b>	5	8
Sodium	ppm	ASTM D5185m	<b>0</b>	2	2
Potassium	ppm	ASTM D5185m >20	<b>2</b>	0	<1

### FLUID CLEANLINESS



	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>---</b>	▲ 82426	---
Particles >6µm	ASTM D7647	>5000	<b>---</b>	▲ 11722	---
Particles >14µm	ASTM D7647	>640	<b>---</b>	237	---
Particles >21µm	ASTM D7647	>160	<b>---</b>	31	---
Particles >38µm	ASTM D7647	>40	<b>---</b>	0	---
Particles >71µm	ASTM D7647	>10	<b>---</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>---</b>	▲ 24/21/15	---

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.85	<b>0.53</b>	0.514	0.545




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 320	<b>281</b>	286	300.5

### SAMPLE IMAGES



### GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC05905410 **Received** : 24 Jul 2023  
**Lab Number** : 05905410 **Diagnosed** : 26 Jul 2023  
**Unique Number** : 10566766 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**AVERY DENNISON CHEMICAL DIVISION**  
 171 DRAKETOWN RD  
 MILL HALL, PA  
 US 17751  
 Contact: DONALD EYER  
 DONALD.EYER@AVERYDENNISON.COM  
 T:  
 F: (570)748-1813

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)