


PROBLEM SUMMARY

Machine Id **LSB-3 (S/N 3235006)** Component

Refrigeration Compressor Fluid USPI ALT-68 SC (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Sample Rating Trend

PROBLEMATIC TEST RESULTS						
Sample Status			ABNORMAL	ATTENTION	ABNORMAL	
Particles >4µm	ASTM D7647	>10000	<u> </u>	9691	A 33818	
Particles >6µm	ASTM D7647	>2500	🔺 13485	A 3168	A 7842	
Particles >14µm	ASTM D7647	>320	<u> </u>	177	A 327	
Particles >21µm	ASTM D7647	>80	<mark>/</mark> 81	31	44	
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<u> </u>	2 0/19/15	▲ 22/20/16	

Customer Id: PREORA Sample No.: USPM5905485 Lab Number: 05905485 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service the filters on this component.		

HISTORICAL DIAGNOSIS



30 Apr 2023 Diag: Doug Bogart

Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

23 Nov 2021 Diag: Doug Bogart



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

24 Feb 2021 Diag: Jonathan Hester

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

Sample Rating Trend

ISO

LSB-3 (S/N 3235006)

Refrigeration Compressor Fluid USPI ALT-68 SC (--- GAL)

DIAGNOSIS

. . . .

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Mar2003	Aug2011 Jan2015	Jul2019 Nov2021	Jul2023	
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM5905485	USP235939	USP208923
Sample Date		Client Info		23 Jul 2023	30 Apr 2023	23 Nov 2021
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	2	1	2
Chromium	ppm	ASTM D5185m	>2	0	2	0
Nickel	ppm	ASTM D5185m		0	<1	<1
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	0	<1	<1
Copper	ppm	ASTM D5185m		0	<1	0
Tin	ppm	ASTM D5185m	>4	0	1	0
Antimony	ppm	ASTM D5185m	21			0
Vanadium	ppm	ASTM D5185m		0	2	0
Cadmium		ASTM D5185m		0	1	0
	ppm			-		-
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		<1	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	<1
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	<1	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	0	6	5
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	10	2	10
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m	>20	<1	5	1
Water	%	ASTM D6304		0.006	0.005	0.006
ppm Water	ppm	ASTM D6304	>100	67.2	52.0	63.6
FLUID CLEANLIN		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	▲ 55332	9691	▲ 33818
Particles >6µm		ASTM D7647		13485	▲ 3168	▲ 7842
Particles >14µm		ASTM D7647	>320	▲ 485	177	▲ 327
Particles >21µm		ASTM D7647		▲ 81	31	44
Particles >38µm		ASTM D7647	>20	1	0	1
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	o ▲ 23/21/16	20/19/15	▲ 22/20/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.015	0.012	0.015
	niy NOR/9	AGTIVI D9/4	0.005	0.015	0.012	0.010


Report Id: PREORA [WUSCAR] 05905485 (Generated: 07/25/2023 12:31:07) Rev: 1


Contact/Location: TIM REINERT - PREORA



OIL ANALYSIS REPORT








55

6/03

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	LIGHT	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	65.6	66.4	66.6	67.0
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color					944 58%-262	
					Provent in the	

Bottom



Contact/Location: TIM REINERT - PREORA