




PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
FLEX VAC 2 (S/N 5588197)
 Component
Pump
 Fluid
USPI MAX FG VAC 100 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	NORMAL	NORMAL
Particles >6µm	ASTM D7647 >1300	▲ 1354	157	132
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 19/18/14	16/14/11	16/14/10

Customer Id: FARDEN
 Sample No.: USPM905487
 Lab Number: 05905487
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

09 Apr 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



05 Jan 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



28 Sep 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
FLEX VAC 2 (S/N 5588197)

Component
Pump
Fluid
USPI MAX FG VAC 100 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USPM905487	USPM28617	USPM26089
Sample Date	Client Info	23 Jul 2023	09 Apr 2023	05 Jan 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ATTENTION	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >90	0	0
Chromium	ppm	ASTM D5185m >5	0	0
Nickel	ppm	ASTM D5185m >5	0	<1
Titanium	ppm	ASTM D5185m >3	0	0
Silver	ppm	ASTM D5185m >3	0	<1
Aluminum	ppm	ASTM D5185m >7	0	0
Lead	ppm	ASTM D5185m >12	0	0
Copper	ppm	ASTM D5185m >30	0	0
Tin	ppm	ASTM D5185m >9	0	0
Vanadium	ppm	ASTM D5185m	0	0
Cadmium	ppm	ASTM D5185m	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0
Barium	ppm	ASTM D5185m	<1	1
Molybdenum	ppm	ASTM D5185m	0	0
Manganese	ppm	ASTM D5185m	0	0
Magnesium	ppm	ASTM D5185m	0	<1
Calcium	ppm	ASTM D5185m	0	0
Phosphorus	ppm	ASTM D5185m	0	2
Zinc	ppm	ASTM D5185m	0	3
Sulfur	ppm	ASTM D5185m	0	0

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >60	8	7
Sodium	ppm	ASTM D5185m	0	0
Potassium	ppm	ASTM D5185m >20	<1	<1
Water	%	ASTM D6304	0.021	0.011
ppm Water	ppm	ASTM D6304 >.1	210.3	118.3


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	4672	449	498
Particles >6µm	ASTM D7647 >1300	▲ 1354	157	132
Particles >14µm	ASTM D7647 >160	87	18	9
Particles >21µm	ASTM D7647 >40	17	6	2
Particles >38µm	ASTM D7647 >10	0	0	0
Particles >71µm	ASTM D7647 >3	0	0	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 19/18/14	16/14/11	16/14/10


FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.074	0.06


Particle Trend




Water




Acid Number



Water



Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	104	99.5	107

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM905487 **Received** : 24 Jul 2023
Lab Number : 05905487 **Diagnosed** : 25 Jul 2023
Unique Number : 10566843 **Diagnostician** : Doug Bogart
Test Package : IND 2

SMITHFIELD - DENISON - SMIDENIOW
 800 INDUSTRIAL ROAD
 DENISON, IA
 US 51442
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (712)263-7414

F: (712)263-7314