




PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY




Machine Id
003-137143
Component
Air Compressor
Fluid
USPI AIR 46 (--- LTR)



COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ATTENTION	NORMAL
Debris	scalar	*Visual	NONE	▲ MODER	LIGHT	NONE
Visc @ 40°C	cSt	ASTM D445	49.7	▲ 34.9	▲ 31.8	43.2

Customer Id: PREORA
Sample No.: USPM5905517
Lab Number: 05905517
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

05 Jul 2023 Diag: Doug Bogart

VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The oil viscosity is lower than normal. Confirmed. The AN level is acceptable for this fluid.

[view report](#)



02 Nov 2021 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



26 Jul 2021 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Machine Id
003-137143
 Component
Air Compressor
 Fluid
USPI AIR 46 (--- LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The oil viscosity remains lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USPM5905517	USPM28102	USPM20570
Sample Date	Client Info	23 Jul 2023	05 Jul 2023	02 Nov 2021
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ATTENTION	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	0	0
Chromium	ppm	ASTM D5185m >4	0	0
Nickel	ppm	ASTM D5185m >4	0	0
Titanium	ppm	ASTM D5185m	0	0
Silver	ppm	ASTM D5185m	<1	<1
Aluminum	ppm	ASTM D5185m >10	0	<1
Lead	ppm	ASTM D5185m >20	0	0
Copper	ppm	ASTM D5185m >40	0	<1
Tin	ppm	ASTM D5185m >5	0	<1
Antimony	ppm	ASTM D5185m	---	---
Vanadium	ppm	ASTM D5185m	0	<1
Cadmium	ppm	ASTM D5185m	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0
Barium	ppm	ASTM D5185m 0	<1	7
Molybdenum	ppm	ASTM D5185m 0	0	0
Manganese	ppm	ASTM D5185m	0	0
Magnesium	ppm	ASTM D5185m 0	0	0
Calcium	ppm	ASTM D5185m 0	0	0
Phosphorus	ppm	ASTM D5185m 1	8	1
Zinc	ppm	ASTM D5185m 0	0	0
Sulfur	ppm	ASTM D5185m 0	0	18

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	0	<1
Sodium	ppm	ASTM D5185m	0	<1
Potassium	ppm	ASTM D5185m >20	<1	1
Water	%	ASTM D6304 >0.2	0.057	0.047
ppm Water	ppm	ASTM D6304 >2000	577.5	479.4

FLUID CLEANLINESS




method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	---	7098	2059
Particles >6µm	ASTM D7647 >2500	---	1892	423
Particles >14µm	ASTM D7647 >320	---	86	24
Particles >21µm	ASTM D7647 >80	---	21	6
Particles >38µm	ASTM D7647 >20	---	0	0
Particles >71µm	ASTM D7647 >4	---	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	---	20/18/14	18/16/12

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.05	0.11	0.08




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	49.7 ▲ 34.9	▲ 31.8	43.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM5905517 **Received** : 24 Jul 2023
Lab Number : 05905517 **Diagnosed** : 25 Jul 2023
Unique Number : 10566873 **Diagnostician** : Doug Bogart
Test Package : IND 2

PREMIUM PET HEALTH - SMITHFIELD (SMIORA)
 101 14TH ST SE
 ORANGE CITY, IA
 US 51041
 Contact: TIM REINERT

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (712)737-5739
 F: