



PROBLEM SUMMARY


Machine Id 8176150 (S/N 1032) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY







RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ATTENTION	ABNORMAL		
Silicon	ppm	ASTM D5185m	>25	<u> </u>	24	▲ 34		
Particles >6µm		ASTM D7647	>1300	🔺 5623	1 378	579		
Particles >14µm		ASTM D7647	>80	<u> </u>	112	24		
Particles >21µm		ASTM D7647	>20	A 75	<u> </u>	7		
Oil Cleanliness		ISO 4406 (c)	>17/13	<u> </u>	1 8/14	16/12		

Customer Id: ALUPIE Sample No.: KC05905530 Lab Number: 05905530 Test Package: IND 2



To manage this report scan the QR code


To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS





No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

17 Jan 2023 Diag: Don Baldridge



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. Elemental level of silicon (Si) above normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report


02 Nov 2022 Diag: Don Baldridge

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. Elemental level of silicon (Si) above normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



current

history1

history2

Machine Id 8176150 (S/N 1032) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05905530	KC102634	KC103545
Sample Date		Client Info		20 Jul 2023	10 Apr 2023	17 Jan 2023
Machine Age	hrs	Client Info		15543	13205	11222
Oil Age	hrs	Client Info		0	1983	8002
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				ABNORMAL	ATTENTION	ABNORMAL
-						
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	3	7
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	<1	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	0	15	0
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	1	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon			>25	▲ 32	24	▲ 34
	ppm		>20	0	6	0
Sodium	ppm	ASTM D5185m	. 00	-		<1
Potassium Water	ppm %	ASTM D5185m ASTM D6304	>20 >0.05	1 0.007	3 0.007	< 1 0.008
ppm Water	ppm	ASTM D6304	>500	77.3	73.0	87.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		21859	4545	3477
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u> </u>	579
Particles >14µm		ASTM D7647	>80	<u> </u>	1 12	24
Particles >21µm		ASTM D7647	>20	<u> </u>	<u> </u>	7
Particles >38µm		ASTM D7647	>4	3	1	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>17/13	A 20/15	▲ 18/14	16/12
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.48	0.42	0.49
. /	- 0					


limit/haco



OIL ANALYSIS REPORT







ua5/22

2°0 48

0.24


0.00

eb1

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.1	44.1	44.1
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color						



Bottom



Contact/Location: CHRIS SHOUE - ALUPIE