


PROBLEM SUMMARY


THODELIN COMMAN


SULLUBE Machine Id SULLAIR 200909100028 - VEOLIA


Component Compressor



COMPONENT CONDITION SUMMARY







RECOMMENDATION

We advise that you check for a possible overheat condition. Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS								
Sample Status	ample Status SEVERE SEVERE SEVERE							
Water	%	ASTM D6304	>0.1	△ 0.646				
ppm Water	ppm	ASTM D6304	>1000	460				
Acid Number (AN)	mg KOH/g	ASTM D8045	.06	13.58	3.969	16.42		
Visc @ 40°C	cSt	ASTM D445	38.1	79.8	<u> </u>	<u> </u>		

Customer Id: UCTATRIC Sample No.: UCH05905628 Lab Number: 05905628 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.		
Flush System			?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.		
Resample			?	We recommend an early resample to monitor this condition.		
Check For Overheating			?	We advise that you check for a possible overheat condition.		

HISTORICAL DIAGNOSIS

27 Apr 2023 Diag: Don Baldridge

DEGRADATION



We advise that you check for a possible overheat condition. Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is well above the recommended limit. The oil viscosity is higher than normal. TAN level indicates possible presence of varnish. The oil is no longer serviceable.



28 Mar 2023 Diag: Jonathan Hester

DEGRADATION



We advise that you check for a possible overheat condition. Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is well above the recommended limit. The oil viscosity is higher than normal. TAN level indicates possible presence of varnish. The oil is no longer serviceable.



07 Mar 2023 Diag: Jonathan Hester

DEGRADATION



We advise that you check for a possible overheat condition. Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is above the recommended limit. The oil viscosity is higher than normal. TAN level indicates possible presence of varnish. The oil is no longer serviceable.






OIL ANALYSIS REPORT

OIL ANALTOIO HEI OIL

SULLUBE Machine Id SULLAIR 200909100028 - VEOLIA

Compressor



DIAGNOSIS

Recommendation

We advise that you check for a possible overheat condition. Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is above the recommended limit. The oil viscosity is higher than normal. TAN level indicates possible presence of varnish. The oil is no longer serviceable.

		Sep 2018	Apr2021 Sep2021	Feb2023 Mar2023	Jul2023	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH05905628	UCH05839329	UCH0581398
Sample Date		Client Info		14 Jul 2023	27 Apr 2023	28 Mar 2023
Machine Age	hrs	Client Info		64986	63298	62589
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				SEVERE	SEVERE	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	38	1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	0	0
Lead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	5	<1	<1
Tin	ppm	ASTM D5185m	>15	1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		4	0	0
Barium	ppm	ASTM D5185m	745	484	134	303
Molybdenum	ppm	ASTM D5185m	0.0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	0.0	2	<1	4
Calcium	ppm	ASTM D5185m	1	4	2	3
Phosphorus	ppm	ASTM D5185m	3	14	8	11
Zinc	ppm	ASTM D5185m	0.1	12	<1	4
Sulfur	ppm	ASTM D5185m	240	472	422	594
CONTAMINANT	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	2	1
Sodium	ppm	ASTM D5185m		25	18	28
Potassium	ppm	ASTM D5185m	>20	4	3	4
Water	%	ASTM D6304	>0.1	△ 0.646		
ppm Water	ppm	ASTM D6304	>1000	△ 6460		
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	ma KOU/~	VCTM DOUVE	06	12 50	2 060	16.40

13.58

Acid Number (AN)

mg KOH/g ASTM D8045 .06

3.969

16.42



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package : IND 2 (Additional Tests: KF)

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH05905628 : 05905628

: 10566984

Received : 24 Jul 2023 Diagnosed : 26 Jul 2023 Diagnostician : Don Baldridge

RICHMOND, VA US 23237 Contact: KEITH GLEASON

KEITH.GLEASON@TATE.COM To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (804)743-0415

TATE ENGINEERING

8131 VIRGINIA PINE CT

T: