

OIL ANALYSIS REPORT

Sample Rating Trend



Area **49 Machine Id [49] A49 FAN 1** Component Center Gearbox Fluid GEAR LIFE 150 (5 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





2017 May2018 May2019 May2020 Feb2021 Nov2021 Aug2022 May2023

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		HPL0003183	HPL0002776	HPL0001909
Sample Date		Client Info		18 Jul 2023	05 May 2023	09 Feb 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		6730	5650	4570
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	160	165	120
Chromium	ppm	ASTM D5185m	>10	<1	<1	<1
Nickel	ppm	ASTM D5185m	>10	0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	<1	0
Lead	ppm	ASTM D5185m	>50	0	<1	<1
Copper	ppm	ASTM D5185m	>200	0	<1	<1
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		<1	0	0
Molybdenum	ppm	ASTM D5185m		<1	<1	<1
Manganese	ppm	ASTM D5185m		2	2	2
Magnesium	ppm	ASTM D5185m		4	3	3
Calcium	ppm	ASTM D5185m		12	7	5
Phosphorus	ppm	ASTM D5185m		210	188	193
Zinc	ppm	ASTM D5185m		29	16	4
Sulfur	ppm	ASTM D5185m		25822	21313	23262
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<1	<1	1
Sodium	ppm	ASTM D5185m		2	0	2
Potassium	ppm	ASTM D5185m	>20	3	4	<1
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42	0.48	0.52
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
2.05.10) Dov: 1					Submitted P	



OIL ANALYSIS REPORT



Aug2/22 May5/23 lav18/20 Feb25/21 Vov17/21 KENSING 2525 S KENSINGTON RD KANKAKEE, IL US 60901 Contact: TIM HUBERT timothy.hubert@kensingsolutions.com T: (815)939-8918 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: x:

155

154

no image

no image

Nov17/21

lov17/21

Ig2/22

g2/22

/lav18/20

/lav18/20

/lav24/1

May/24/19

Mav18/20

eb25/2

ah75/7

Ch75/7

av24/1

ug2/22

w5/73

Certificate L2367

Laboratory

Sample No.

Lab Number

Unique Number

Test Package : MOB 2

: HPL0003183

: 05905643

: 10566999

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Diagnostician : Wes Davis

: 24 Jul 2023

: 25 Jul 2023

Received

Diagnosed

Submitted By: TIM HUBERT

Page 2 of 2