




Machine Id 6383655 (S/N 1165) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Sample Status ABNORMAL ABNORMAL Particles >6µm ASTM D7647 >1300 4698 ▲ 6607 Particles >14µm ASTM D7647 >80 **456 A** 996 Particles >21µm ASTM D7647 >20 **116**

ISO 4406 (c) >--/17/13 **A 21/19/16**

PROBLEMATIC TEST RESULTS

Oil Cleanliness


Customer Id: SMAFOR Sample No.: KC05922189 Lab Number: 05922189 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 <u>jhester@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



ABNORMAL

21/20/17

RECOMMENDED ACTIONS


There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

09 Sep 2022 Diag: Doug Bogart

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

31 Jan 2022 Diag: Don Baldridge



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

15 Apr 2021 Diag: Doug Bogart

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







view report



OIL ANALYSIS REPORT



Machine Id 6383655 (S/N 1165) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05922189	KCP49390	KCP48692
Sample Date		Client Info		28 Jul 2023	09 Sep 2022	31 Jan 2022
Machine Age	hrs	Client Info		20017	17030	13972
Oil Age	hrs	Client Info		0	3058	4516
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
-						
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	3
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	1	22	16
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	48	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	90	78	12	27
Calcium	ppm	ASTM D5185m		0	0	<1
Phosphorus	ppm	ASTM D5185m		12	9	10
Zinc	ppm	ASTM D5185m		0	23	27
				-		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	<1
Sodium	ppm	ASTM D5185m		4	4	9
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.05	0.016	0.012	0.007
ppm Water	ppm	ASTM D6304	>500	169.5	128.6	70.5
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		13797	15343	
Particles >6µm		ASTM D7647	>1300	<u> </u>	▲ 6607	
Particles >14µm		ASTM D7647	>80	456	9 96	
Particles >21µm		ASTM D7647	>20	<u> </u>	1 88	
Particles >38µm		ASTM D7647	>4	3	<u> </u>	
Particles >71µm		ASTM D7647	>3	0	1	
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 21/19/16	▲ 21/20/17	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.33	0.336	0.32
			2		0.000	0.01

Contact/Location: Service Manager - SMAFOR



(^B/H0) Ē0.3

OIL ANALYSIS REPORT

scalar

scalar

scalar

scalar

scalar

scalar

scalar

method

*Visual

*Visual

*Visual

*Visual

*Visual

*Visua

*Visual

scalar *Visual

limit/base

NONE

NONE

NONE


NONE


NONE

NONE

NORML

NORML





current

NONE

NONE

NONE

NONE

LIGHT

NONE

NORML

NORML

history1

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

history2

NONE

NONE

NONE

NONE


A MODER

NONE

NORML

NORML

Bottom



Contact/Location: Service Manager - SMAFOR