

No relevant graphs to display

RECOMMENDATION	PROBLEMATIC TEST RESULTS			
The filter change at the time of sampling has been	Sample Status	ABNORMAL	ABNORMAL	ABNORMAL

noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC T	EST RE	SULTS				
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Debris	scalar	*Visual	NONE	🔺 MODER	LIGHT	A MODER

Customer Id: SMAFOR Sample No.: KC05922190 Lab Number: 05922190 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDE	ED ACTIONS			
Action	Status	Date	Done By	I
Alert			?	1

#### Description

We were unable to perform a particle count due to a high concentration of particles present in this sample.

#### HISTORICAL DIAGNOSIS



09 Sep 2022 Diag: Doug Bogart

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 14 Feb 2022 Diag: Jonathan Hester

WATER



We advise that you stop the unit and follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Appearance is hazy. Free water present. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





#### 15 Apr 2021 Diag: Doug Bogart

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**





Machine Id 7228740 (S/N 1109) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

#### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## Wear

All component wear rates are normal.

#### Contamination

Moderate concentration of visible dirt/debris present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05922190	KCP49391	KCP48695
Sample Date		Client Info		28 Jul 2023	09 Sep 2022	14 Feb 2022
Machine Age	hrs	Client Info		15960	12424	8830
Oil Age	hrs	Client Info		0	3000	4417
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	0
Chromium	ppm	ASTM D5185m		0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m		1	<1	<1
Lead		ASTM D5185m	>10	0	0	<1
	ppm	ASTM D5185m		27	30	14
Copper Tin	ppm	ASTM D5185m ASTM D5185m	>50 >10	0	30 0	0
	ppm		>10			
Antimony Vanadium	ppm	ASTM D5185m ASTM D5185m		 <1		0
	ppm				0	
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	90	0	0	7
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		<1	11	10
Zinc	ppm	ASTM D5185m		0	2	55
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	2
Sodium	ppm	ASTM D5185m		<1	<1	32
Potassium	ppm	ASTM D5185m	>20	0	<1	9
Water	%	ASTM D6304	>0.05	0.001	0.015	<b>0</b> .119
ppm Water	ppm	ASTM D6304	>500	14.0	158.9	▲ 1190
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			35209	
Particles >6µm		ASTM D7647	>1300		<b>6</b> 715	
Particles >14µm		ASTM D7647	>80		<b>6</b> 93	
Particles >21µm		ASTM D7647	>20		<b>1</b> 48	
Particles >38µm		ASTM D7647	>4		<b></b> 7	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		▲ 22/20/17	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.28	0.21	0.13
					'	



38

Apr15/21.


# **OIL ANALYSIS REPORT**




Feb14/22

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	A MODER	LIGHT	🔺 MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	🔺 HAZY
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	<b>▲</b> 1.0
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	43.9	43.3	43.4
SAMPLE IMAGES	S	method	limit/base	current	history1	history2

Color



Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: Service Manager - SMAFOR