PROBLEM SUMMARY

Sample Rating Trend



ISO

Area
Fermentation
Machine Id
Lightnin FHG51AB01 Main Fermentor, Agitator
Component
Gearbox
Fluid
JAX FGG-AW ISO 220 (46 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time.
Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				**ABNORMAL**	ABNORMAL	ABNORMAL
Particles >4µm		ASTM D7647	>20000	▲ **117669**	▲ 118934	▲ 174753
Particles >6µm		ASTM D7647	>5000	▲ **8710**	▲ 30752	▲ 24953
Oil Cleanliness		ISO 4406 (c)	>21/19/16	▲ **24/20/14**	▲ 24/22/17	▲ 25/22/14

Customer Id: NOVFRANC
Sample No.: WC0835750
Lab Number: 05922228
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

17 May 2023 Diag: Doug Bogart

ISO

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

27 Jan 2023 Diag: Doug Bogart

ISO

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

25 Oct 2022 Diag: Angela Borella

ISO

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
Fermentation
Machine Id
Lightnin FHG51AB01 Main Fermentor, Agitator
Component
Gearbox
Fluid
JAX FGG-AW ISO 220 (46 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0835750**	WC0793865	WC0745862
Sample Date		Client Info		**09 Aug 2023**	17 May 2023	27 Jan 2023
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	**22**	22	22
Chromium	ppm	ASTM D5185m	>15	**0**	0	0
Nickel	ppm	ASTM D5185m	>15	**0**	<1	0
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>25	**2**	0	0
Lead	ppm	ASTM D5185m	>100	**0**	0	0
Copper	ppm	ASTM D5185m	>200	**<1**	<1	0
Tin	ppm	ASTM D5185m	>25	**0**	0	0
Vanadium	ppm	ASTM D5185m		**<1**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	0
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**0**	<1	0
Manganese	ppm	ASTM D5185m		**<1**	<1	0
Magnesium	ppm	ASTM D5185m		**0**	<1	0
Calcium	ppm	ASTM D5185m		**0**	2	2
Phosphorus	ppm	ASTM D5185m		**538**	590	540
Zinc	ppm	ASTM D5185m		**5**	14	12
Sulfur	ppm	ASTM D5185m		**944**	952	662

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	**2**	3	2
Sodium	ppm	ASTM D5185m		**1**	0	0
Potassium	ppm	ASTM D5185m	>20	**0**	<1	<1
Water	%	ASTM D6304	>0.2	**0.002**	0.013	0.014
ppm Water	ppm	ASTM D6304	>2000	**22.5**	139.5	143.5

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ **117669**	▲ 118934	▲ 174753
Particles >6µm	ASTM D7647	>5000	▲ **8710**	▲ 30752	▲ 24953
Particles >14µm	ASTM D7647	>640	**143**	▲ 1075	84
Particles >21µm	ASTM D7647	>160	**32**	▲ 217	3
Particles >38µm	ASTM D7647	>40	**2**	3	0
Particles >71µm	ASTM D7647	>10	**0**	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ **24/20/14**	▲ 24/22/17	▲ 25/22/14

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.79**	0.79	0.75

OIL ANALYSIS REPORT

Particle Trend



Water



Acid Number



Water



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	**226**	228	225

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0835750 **Received** : 11 Aug 2023
Lab Number : 05922228 **Diagnosed** : 14 Aug 2023
Unique Number : 10602175 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NOVOZYMES
P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD
FRANKLINTON, NC
US 27525
Contact: BRUCE THOMAS
brct@novozymes.com
T: (919)494-3146
F: (919)494-3456