


# PROBLEM SUMMARY

Area  
**HERTZ**  
Machine Id  
**HERTZ HBD00117 - COMPLEAT STAIR**  
Component  
**Compressor**  
Fluid  
**SMARTOIL 6000 (--- GAL)**

Sample Rating Trend



**WATER**



## COMPONENT CONDITION SUMMARY

No relevant graphs to display

## RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

| Sample Status |        |         | ATTENTION | NORMAL | ATTENTION |
|---------------|--------|---------|-----------|--------|-----------|
| Free Water    | scalar | *Visual | ▲ 1.0     | NEG    | ▲ 1.0     |

**Customer Id:** UCATLHER  
**Sample No.:** UHK05922312  
**Lab Number:** 05922312  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

| Action        | Status | Date | Done By | Description   |
|---------------|--------|------|---------|---|
| Change Fluid  | ---    | ---  | ?       | Oil and filter change at the time of sampling has been noted. |
| Change Filter | ---    | ---  | ?       | Oil and filter change at the time of sampling has been noted. |

## HISTORICAL DIAGNOSIS

### 21 Feb 2023 Diag: Angela Borella

NORMAL



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



### 23 Aug 2022 Diag: Jonathan Hester

WATER



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. Free water present. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 11 May 2021 Diag: Angela Borella

WATER




Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area  
**HERTZ**  
Machine Id  
**HERTZ HBD00117 - COMPLEAT STAIR**  
Component  
**Compressor**  
Fluid  
**SMARTOIL 6000 (--- GAL)**



**DIAGNOSIS**

**Recommendation**  
Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

**Wear**  
All component wear rates are normal.

**Contamination**  
Free water present.

**Fluid Condition**  
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

**SAMPLE INFORMATION**

|               | method      | limit/base  | current            | history1    | history2    |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info |             | <b>UHK05922312</b> | UHK05807727 | UHK0000427  |
| Sample Date   | Client Info |             | <b>28 Jul 2023</b> | 21 Feb 2023 | 23 Aug 2022 |
| Machine Age   | hrs         | Client Info | <b>8601</b>        | 6987        | 5433        |
| Oil Age       | hrs         | Client Info | <b>4697</b>        | 1550        | 467         |
| Oil Changed   | Client Info |             | <b>Changed</b>     | Not Changd  | Changed     |
| Sample Status |             |             | <b>ATTENTION</b>   | NORMAL      | ATTENTION   |

**WEAR METALS**

|          | method | limit/base      | current      | history1 | history2 |
|----------|--------|-----------------|--------------|----------|----------|
| Iron     | ppm    | ASTM D5185m >50 | <b>1</b>     | 0        | <1       |
| Chromium | ppm    | ASTM D5185m >10 | <b>0</b>     | 0        | 0        |
| Nickel   | ppm    | ASTM D5185m     | <b>&lt;1</b> | 0        | 0        |
| Titanium | ppm    | ASTM D5185m     | <b>0</b>     | 0        | 0        |
| Silver   | ppm    | ASTM D5185m     | <b>0</b>     | 0        | <1       |
| Aluminum | ppm    | ASTM D5185m >25 | <b>1</b>     | <1       | <1       |
| Lead     | ppm    | ASTM D5185m >25 | <b>0</b>     | 0        | <1       |
| Copper   | ppm    | ASTM D5185m >50 | <b>&lt;1</b> | 1        | 1        |
| Tin      | ppm    | ASTM D5185m >15 | <b>&lt;1</b> | 0        | 2        |
| Antimony | ppm    | ASTM D5185m     | <b>---</b>   | ---      | ---      |
| Vanadium | ppm    | ASTM D5185m     | <b>0</b>     | 0        | 0        |
| Cadmium  | ppm    | ASTM D5185m     | <b>0</b>     | 0        | 0        |

**ADDITIVES**

|            | method | limit/base     | current      | history1 | history2 |
|------------|--------|----------------|--------------|----------|----------|
| Boron      | ppm    | ASTM D5185m    | <b>0</b>     | 0        | 0        |
| Barium     | ppm    | ASTM D5185m    | <b>0</b>     | 0        | 0        |
| Molybdenum | ppm    | ASTM D5185m    | <b>0</b>     | 0        | 0        |
| Manganese  | ppm    | ASTM D5185m    | <b>&lt;1</b> | 0        | <1       |
| Magnesium  | ppm    | ASTM D5185m    | <b>0</b>     | 0        | 1        |
| Calcium    | ppm    | ASTM D5185m 20 | <b>0</b>     | 0        | 3        |
| Phosphorus | ppm    | ASTM D5185m    | <b>577</b>   | 669      | 37       |
| Zinc       | ppm    | ASTM D5185m    | <b>0</b>     | 0        | 35       |
| Sulfur     | ppm    | ASTM D5185m    | <b>776</b>   | 781      | 100      |




**CONTAMINANTS**

|           | method | limit/base       | current      | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon   | ppm    | ASTM D5185m >25  | <b>3</b>     | 4        | 8        |
| Sodium    | ppm    | ASTM D5185m      | <b>&lt;1</b> | 0        | 0        |
| Potassium | ppm    | ASTM D5185m >20  | <b>&lt;1</b> | 0        | 1        |
| Water     | %      | ASTM D6304 >0.1  | <b>0.036</b> | ---      | 0.079    |
| ppm Water | ppm    | ASTM D6304 >1000 | <b>360</b>   | ---      | 790      |

**FLUID DEGRADATION**

|                  | method   | limit/base | current     | history1 | history2 |
|------------------|----------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | <b>0.23</b> | 0.19     | 0.17     |

# OIL ANALYSIS REPORT







| VISUAL           | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Yellow Metal     | scalar | *Visual    | NONE    | NONE     | NONE     |
| Precipitate      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Silt             | scalar | *Visual    | NONE    | NONE     | NONE     |
| Debris           | scalar | *Visual    | NONE    | MODER    | LIGHT    |
| Sand/Dirt        | scalar | *Visual    | NONE    | NONE     | NONE     |
| Appearance       | scalar | *Visual    | NORML   | NORML    | NORML    |
| Odor             | scalar | *Visual    | NORML   | NORML    | NORML    |
| Emulsified Water | scalar | *Visual    | >0.1    | NEG      | 0.2%     |
| Free Water       | scalar | *Visual    | ▲ 1.0   | NEG      | ▲ 1.0    |

| FLUID PROPERTIES | method | limit/base   | current | history1 | history2 |
|------------------|--------|--------------|---------|----------|----------|
| Visc @ 40°C      | cSt    | ASTM D445 46 | 50.9    | 44.6     | 55.5     |

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : UHK05922312 **Received** : 11 Aug 2023  
**Lab Number** : 05922312 **Diagnosed** : 14 Aug 2023  
**Unique Number** : 10602259 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF )

**ATLANTA AIR COMPRESSOR - HERTZ**  
 123 MERCHANTS PARK DR  
 HOSCHTON, GA  
 US 30548  
 Contact: Service Manager

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)