

OIL ANALYSIS REPORT

SMART OIL Machine Id HERTZ VD019011 - H & F BREAD

Component

Compressor

SMARTOIL 6000 (--- GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				May2023		
SAMPLE INFORM	AATION	method	limit/base	current	history1	history2
	WATION		IIIIII/Dase			
Sample Number		Client Info		UHK05922319		
Sample Date		Client Info		25 May 2023		
Machine Age	hrs	Client Info		4083		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		4		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	1		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
	nnm	ASTM D5185m				
Boron	ppm			0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m				
Manganese Magnesium	ppm	ASTM D5185m ASTM D5185m		<1 2		
Calcium	ppm	ASTM D5185m	20	0		
Phosphorus	ppm	ASTM D5185m	20	37		
Zinc	ppm	ASTM D5185m		6		
Sulfur	ppm	ASTM D5185m		220		
	ppm					
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	6		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		80.0		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	MODER		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

Unique Number : 10602266

: UHK05922319 : 05922319 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 11 Aug 2023

Diagnosed : 14 Aug 2023 Diagnostician : Don Baldridge ATLANTA AIR COMPRESSOR - HERTZ 123 MERCHANTS PARK DR

HOSCHTON, GA US 30548

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: