




PROBLEM SUMMARY

Sample Rating Trend




WEAR




Area
Milliken
 Machine Id
INGERSOLL RAND EE4347U19082 - MILLIKEN
 Component
Compressor
 Fluid
INGERSOLL-RAND SSR ULTRA COOLANT (--- GAL)

COMPONENT CONDITION SUMMARY

Non-ferrous Metals



Particle Trend



RECOMMENDATION

The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE	
Tin	ppm	ASTM D5185m	>15	183	124	179
Particles >4µm		ASTM D7647	>10000	50248	60017	107455
Particles >6µm		ASTM D7647	>2500	10570	17534	33912
Oil Cleanliness		ISO 4406 (c)	>20/18/15	23/21/15	23/21/16	24/22/17

Customer Id: AIRALLPA
 Sample No.: APCI2320835
 Lab Number: 05922854
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Service/change Fluid	---	---	?	The oil is near the end of it's useful service life, recommend schedule an oil change.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

30 May 2023 Diag: Don Baldrige

WEAR



The oil is near the end of it's useful service life, recommend schedule an oil change. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. The tin level is severe. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

view report



23 Jan 2023 Diag: Jonathan Hester

WEAR



The oil is near the end of it's useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition. The tin level is severe. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

view report



02 Dec 2022 Diag: Doug Bogart

WEAR



The oil is near the end of it's useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition. The tin level is severe. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is at the top-end of the recommended limit.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
Milliken
 Machine Id
INGERSOLL RAND EE4347U19082 - MILLIKEN
 Component
Compressor
 Fluid
INGERSOLL-RAND SSR ULTRA COOLANT (--- GAL)

DIAGNOSIS

Recommendation

The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition.

Wear

The tin level is severe. All other component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		APCI2320835	APC0000298	APC0000296
Sample Date	Client Info		08 Aug 2023	30 May 2023	23 Jan 2023
Machine Age	hrs	Client Info	32420	30747	0
Oil Age	hrs	Client Info	6000	1000	0
Oil Changed	Client Info		N/A	Not Changd	N/A
Sample Status			SEVERE	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	3	1	2
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m	0	0	<1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	1	0	0
Lead	ppm	ASTM D5185m >25	<1	0	0
Copper	ppm	ASTM D5185m >50	<1	<1	<1
Tin	ppm	ASTM D5185m >15	183	124	179
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	<1
Barium	ppm	ASTM D5185m 500	480	691	318
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	0
Magnesium	ppm	ASTM D5185m 0	<1	0	2
Calcium	ppm	ASTM D5185m 0	2	1	5
Phosphorus	ppm	ASTM D5185m 20	7	0	13
Zinc	ppm	ASTM D5185m 0	14	<1	7
Sulfur	ppm	ASTM D5185m 200	348	310	350

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	2	1	2
Sodium	ppm	ASTM D5185m	33	33	68
Potassium	ppm	ASTM D5185m >20	9	5	11
Water	%	ASTM D6304 >0.1	0.568	0.472	0.298
ppm Water	ppm	ASTM D6304 >1000	5682.9	4720.7	2986.6






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	50248	60017	107455
Particles >6µm	ASTM D7647	>2500	10570	17534	33912
Particles >14µm	ASTM D7647	>320	189	450	689
Particles >21µm	ASTM D7647	>80	43	94	96
Particles >38µm	ASTM D7647	>20	2	4	8
Particles >71µm	ASTM D7647	>4	0	0	1
Oil Cleanliness	ISO 4406 (c)	>20/18/15	23/21/15	23/21/16	24/22/17

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.52	0.42	1.19


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	49.4	53.7	52.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : APCI2320835 **Received** : 11 Aug 2023
Lab Number : 05922854 **Diagnosed** : 14 Aug 2023
Unique Number : 10602801 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, PrtCount)

AIR PRODUCTS AND CHEMICALS INC - ALLENTOWN
 7201 HAMILTON BLVD
 ALLENTOWN, PA
 US 18195
 Contact: MICHAEL PROTZEK
 protzema@airproducts.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)