


Machine Id 41 Component Turbine

Fluid

PROBLEM SUMMARY



No relevant graphs to display

R&O OIL ISO 68 (--- QTS)

COMPONENT CONDITION SUMMARY

RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample.

PROBLEMATIC T	EST RE	SULTS				
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
White Metal	scalar	*Visual	NONE	🔺 MODER	NONE	LIGHT

Customer Id: COLALB Sample No.: WC0813255 Lab Number: 05923388 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED	ACTIONS			
Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component if applicable.
Alert			?	We were unable to perform a particle count due to metal particles present in this sample.

HISTORICAL DIAGNOSIS



14 Sep 2022 Diag: Jonathan Hester

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

16 Nov 2021 Diag: Doug Bogart



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

08 Sep 2020 Diag: Don Baldridge



No corrective action is recommended at this time. Resample at the next service interval to monitor. The iron level is abnormal. All other component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

Sample Rating Trend

VISUAL METAL

Machine Id **41** Component **Turbine** Fluid **R&O OIL ISO 68 (--- QTS)**

DIAGNOSIS

A Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample.

🔺 Wear

Moderate concentration of visible metal present. All component wear rates are normal.

Contamination

No other contaminants were detected in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


		32005 Apr20	06 Feb2007 May2008	Oct2009 May2011 Jan2015 /	Aug2019	
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0813255	WC0700753	WC0577573
Sample Date		Client Info		13 Aug 2023	14 Sep 2022	16 Nov 2021
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	10	10	23
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	2	0
Lead	ppm	ASTM D5185m		0	<1	<1
Copper	ppm	ASTM D5185m	>5	1	<1	1
Tin	ppm	ASTM D5185m	>5	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0	0	0
Barium	ppm	ASTM D5185m	5	<1	0	0
Molybdenum	ppm	ASTM D5185m	5	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	5	6	0	0
Calcium	ppm	ASTM D5185m	5	<1	0	2
Phosphorus	ppm	ASTM D5185m	100	5	2	5
Zinc	ppm	ASTM D5185m	25	19	0	0
Sulfur	ppm	ASTM D5185m	1500	2	19	117
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	0	<1
Sodium	ppm	ASTM D5185m		1	0	0
Potassium	ppm	ASTM D5185m	>20	0	2	0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			144500	189743
Particles >6µm		ASTM D7647	>1300		<u> </u>	<u> </u>
Particles >14µm		ASTM D7647	>160		16	6 539
Particles >21µm		ASTM D7647	>40		2	6 50
Particles >38µm		ASTM D7647	>10		0	0
Particles >71µm		ASTM D7647	>3		0	0
Oil Cleanliness		ISO 4406 (c)	>/17/14		4/20/11	▲ 25/23/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.08	0.081	0.06	0.06



Sep28/05 Apr27/06

-h13/07

OIL ANALYSIS REPORT




0ct4/09

an 19/15

Aug20/19

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	A MODER	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68	67.5	67.3	68.2
SAMPLE IMAGES	\$	method	limit/base	current	history1	history2
Color						
Bottom						



Contact/Location: STEPHEN MOSS - COLALB