




# PROBLEM SUMMARY

## Sample Rating Trend


ISO



Area  
**Recovery**  
 Machine Id  
**Bornemann FHG25AP01 Decanter Sludge Outlet Flow Pump**  
 Component  
**Gearbox**  
 Fluid  
**JAX Flow-Guard Synthetic 100 (4 QTS)**

## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>20000	▲ 142316	▲ 189262	---
Particles >6µm	ASTM D7647	>5000	▲ 27731	▲ 67583	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/22/16	▲ 25/23/16	---

Customer Id: NOVFRANC  
 Sample No.: WC0827149  
 Lab Number: 05923433  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

## HISTORICAL DIAGNOSIS

**20 Jan 2023 Diag: Jonathan Hester**

### WEAR



We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. Gear wear is indicated. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### WEAR



**09 Nov 2022 Diag: Angela Borella**

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you check all areas where dirt can enter the system. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. Chromium and iron and nickel ppm levels are severe. Copper ppm levels are abnormal. Aluminum ppm levels are noted. Gear wear is indicated. Bearing and/or bushing wear is indicated. There is a high concentration of water present in the oil. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



### ISO



**03 May 2022 Diag: Angela Borella**

If applicable, we advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

## Recovery

Machine Id

### Bornemann FHG25AP01 Decanter Sludge Outlet Flow Pump

Component

### Gearbox

Fluid

### JAX Flow-Guard Synthetic 100 (4 QTS)

#### DIAGNOSIS

##### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

##### Wear

All component wear rates are normal.

##### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

##### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0827149</b>	WC0765176	WC0663723
Sample Date	Client Info	<b>11 Aug 2023</b>	20 Jan 2023	09 Nov 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	SEVERE

#### WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >200	<b>61</b>	▲ 486	● 10000
Chromium ppm	ASTM D5185m >15	<b>&lt;1</b>	10	● 760
Nickel ppm	ASTM D5185m >15	<b>0</b>	2	● 209
Titanium ppm	ASTM D5185m	<b>&lt;1</b>	<1	2
Silver ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum ppm	ASTM D5185m >25	<b>&lt;1</b>	2	▲ 39
Lead ppm	ASTM D5185m >100	<b>0</b>	<1	5
Copper ppm	ASTM D5185m >200	<b>1</b>	3	▲ 181
Tin ppm	ASTM D5185m >25	<b>0</b>	0	3
Vanadium ppm	ASTM D5185m	<b>&lt;1</b>	0	2
Cadmium ppm	ASTM D5185m	<b>0</b>	0	1

#### ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m	<b>0</b>	0	2
Barium ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Molybdenum ppm	ASTM D5185m	<b>0</b>	<1	8
Manganese ppm	ASTM D5185m	<b>1</b>	3	▲ 128
Magnesium ppm	ASTM D5185m	<b>7</b>	<1	8
Calcium ppm	ASTM D5185m	<b>2</b>	1	11
Phosphorus ppm	ASTM D5185m	<b>107</b>	141	203
Zinc ppm	ASTM D5185m	<b>19</b>	0	14
Sulfur ppm	ASTM D5185m	<b>1811</b>	1882	▲ 107

#### CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >50	<b>2</b>	4	▲ 63
Sodium ppm	ASTM D5185m	<b>1</b>	<1	9
Potassium ppm	ASTM D5185m >20	<b>&lt;1</b>	2	10
Water %	ASTM D6304 >0.2	<b>0.008</b>	0.046	● 2.57
ppm Water	ASTM D6304 >2000	<b>80.8</b>	463	● 25700

#### FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ <b>142316</b>	▲ 189262	---
Particles >6µm	ASTM D7647 >5000	▲ <b>27731</b>	▲ 67583	---
Particles >14µm	ASTM D7647 >640	<b>441</b>	363	---
Particles >21µm	ASTM D7647 >160	<b>67</b>	80	---
Particles >38µm	ASTM D7647 >40	<b>2</b>	11	---
Particles >71µm	ASTM D7647 >10	<b>1</b>	0	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ <b>24/22/16</b>	▲ 25/23/16	---


#### FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045	<b>0.38</b>	0.13	0.65




# OIL ANALYSIS REPORT


## Particle Trend




## Water




## Acid Number



## Water




## Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	▲ MILKY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	● 0.2%
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100.0	98.7	102

## SAMPLE IMAGES




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0827149 **Received** : 14 Aug 2023  
**Lab Number** : 05923433 **Diagnosed** : 15 Aug 2023  
**Unique Number** : 10603380 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**NOVOZYMES**  
P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD  
FRANKLINTON, NC  
US 27525  
Contact: BRUCE THOMAS  
brct@novozymes.com  
T: (919)494-3146  
F: (919)494-3456