




# PROBLEM SUMMARY

Sample Rating Trend




VISUAL METAL



Area  
**Recovery**  
 Machine Id  
**Pro Quip FFI56HB01 Standardization Tank, Agitator**  
 Component  
**Gearbox**  
 Fluid  
**JAX MAGNA-PLATE 460 FG (--- GAL)**

## COMPONENT CONDITION SUMMARY

### ▲ Ferrous Alloys



## RECOMMENDATION

We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to metal particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>200	▲ <b>376</b>	10	18
White Metal	scalar	*Visual	NONE	▲ <b>MODER</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ <b>HAZY</b>	NORML	NORML

Customer Id: NOVFRANC  
 Sample No.: WC0827151  
 Lab Number: 05923440  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Alert	---	---	?	We were unable to perform a particle count due to metal particles present in this sample.

## HISTORICAL DIAGNOSIS

### 10 Aug 2022 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 6 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 12 Aug 2021 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 10 Feb 2021 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report





# OIL ANALYSIS REPORT

Sample Rating Trend

VISUAL METAL

Area

## Recovery

Machine Id


### Pro Quip FFI56HB01 Standardization Tank, Agitator

Component

#### Gearbox

Fluid

#### JAX MAGNA-PLATE 460 FG (--- GAL)



## DIAGNOSIS

### Recommendation

We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to metal particles present in this sample.

### Wear

Moderate concentration of visible metal present. Gear wear is indicated.

### Contamination

No other contaminants were detected in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0827151</b>	WC0726001	WC0611282
Sample Date	Client Info		<b>11 Aug 2023</b>	10 Aug 2022	12 Aug 2021
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	<b>▲ 376</b>	10	18
Chromium	ppm	ASTM D5185m >15	<b>2</b>	0	0
Nickel	ppm	ASTM D5185m >15	<b>2</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >200	<b>1</b>	0	<1
Tin	ppm	ASTM D5185m >25	<b>0</b>	0	0
Antimony	ppm	ASTM D5185m >5	<b>---</b>	---	<1
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	3
Barium	ppm	ASTM D5185m	<b>&lt;1</b>	2	0
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Manganese	ppm	ASTM D5185m	<b>4</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>7</b>	0	0
Calcium	ppm	ASTM D5185m	<b>&lt;1</b>	2	3
Phosphorus	ppm	ASTM D5185m	<b>544</b>	576	971
Zinc	ppm	ASTM D5185m	<b>16</b>	2	1
Sulfur	ppm	ASTM D5185m	<b>571</b>	551	906

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>2</b>	2	4
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	0
Water	%	ASTM D6304 >0.2	<b>0.007</b>	0.005	0.003
ppm Water	ppm	ASTM D6304 >2000	<b>76.7</b>	55.0	31.1

## FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>---</b>	<b>▲ 89602</b>	<b>▲ 139189</b>
Particles >6µm	ASTM D7647	>5000	<b>---</b>	4075	<b>▲ 8300</b>
Particles >14µm	ASTM D7647	>640	<b>---</b>	63	65
Particles >21µm	ASTM D7647	>160	<b>---</b>	11	8
Particles >38µm	ASTM D7647	>40	<b>---</b>	0	0
Particles >71µm	ASTM D7647	>10	<b>---</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>---</b>	<b>▲ 24/19/13</b>	<b>▲ 24/20/13</b>

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.64</b>	0.70	0.669




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	▲ MODER	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	460	460	437

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0827151 **Received** : 14 Aug 2023  
**Lab Number** : 05923440 **Diagnosed** : 15 Aug 2023  
**Unique Number** : 10603387 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**NOVOZYMES**  
 P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD  
 FRANKLINTON, NC  
 US 27525  
 Contact: BRUCE THOMAS  
 brct@novozymes.com  
 T: (919)494-3146  
 F: (919)494-3456

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)