




PROBLEM SUMMARY

Sample Rating Trend




VISCOSITY




Area
Recovery
 Machine Id
Lightnin FFI57AB01 Standardization Tank, Agitator
 Component
Gearbox
 Fluid
JAX FGG-AW ISO 150 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Viscosity @ 40°C



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>20000	▲ 146815	▲ 182069	▲ 187297
Particles >6µm	ASTM D7647	>5000	▲ 33080	▲ 45165	▲ 52695
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/22/14	▲ 25/23/15	▲ 25/23/16
Visc @ 40°C	cSt	ASTM D445 150	▲ 175	▲ 180	▲ 179

Customer Id: NOVFRANC
 Sample No.: WC0808208
 Lab Number: 05923441
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

23 Jun 2022 Diag: Don Baldrige

VISCOSITY



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

view report



01 Jul 2021 Diag: Don Baldrige

VISCOSITY



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

view report



17 Dec 2020 Diag: Jonathan Hester

VISCOSITY



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Area

Recovery

Machine Id

Lightnin FFI57AB01 Standardization Tank, Agitator

Component

Gearbox

Fluid

JAX FGG-AW ISO 150 (--- GAL)

DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

▲ Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0808208	WC0706858	WC0589967
Sample Date	Client Info		10 Aug 2023	23 Jun 2022	01 Jul 2021
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>200	44	41	21
Chromium	ppm	ASTM D5185m	>15	0	<1	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	<1	<1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	<1	0	0
Tin	ppm	ASTM D5185m	>25	0	0	0
Antimony	ppm	ASTM D5185m	>5	---	---	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		3	9	5
Barium	ppm	ASTM D5185m		<1	<1	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		8	3	<1
Calcium	ppm	ASTM D5185m		384	527	184
Phosphorus	ppm	ASTM D5185m		466	501	502
Zinc	ppm	ASTM D5185m		36	24	8
Sulfur	ppm	ASTM D5185m		884	924	665

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	2	4	0
Sodium	ppm	ASTM D5185m		1	0	<1
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.2	0.010	0.008	0.003
ppm Water	ppm	ASTM D6304	>2000	105.6	83.0	39.5

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 146815	▲ 182069	▲ 187297
Particles >6µm	ASTM D7647	>5000	▲ 33080	▲ 45165	▲ 52695
Particles >14µm	ASTM D7647	>640	116	274	341
Particles >21µm	ASTM D7647	>160	11	12	11
Particles >38µm	ASTM D7647	>40	0	0	0
Particles >71µm	ASTM D7647	>10	0	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/22/14	▲ 25/23/15	▲ 25/23/16


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.29	0.30	0.230




OIL ANALYSIS REPORT


▲ Particle Trend




Water




▲ Viscosity @ 40°C



Acid Number




Water



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	150 ▲ 175	▲ 180	▲ 179

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


Ferrous Alloys




Non-ferrous Metals




▲ Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0808208
Lab Number : 05923441
Unique Number : 10603388
Test Package : IND 2 (Additional Tests: KF, PrtCount)

Received : 14 Aug 2023
Diagnosed : 15 Aug 2023
Diagnostician : Don Baldrige

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NOVOZYMES
 P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD
 FRANKLINTON, NC
 US 27525
 Contact: BRUCE THOMAS
 brct@novozymes.com
 T: (919)494-3146
 F: (919)494-3456