




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
CATERPILLAR GM02
 Component
Biogas Engine
 Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

We recommend that you drain the oil from the component if this has not already been done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

Wear

Iron ppm levels are severe. Chromium ppm levels are noted. Cylinder, crank, or cam shaft wear is indicated. Ring wear is indicated.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0836320	WC0836354	WC0836317
Sample Date	Client Info		13 Aug 2023	09 Aug 2023	07 Aug 2023
Machine Age	hrs	Client Info	64500	64452	64416
Oil Age	hrs	Client Info	85	37	1
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >45	121	64	31
Chromium	ppm	ASTM D5185m >2	2	<1	<1
Nickel	ppm	ASTM D5185m >2	0	<1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >5	0	0	0
Aluminum	ppm	ASTM D5185m >10	2	2	<1
Lead	ppm	ASTM D5185m >5	0	2	0
Copper	ppm	ASTM D5185m >14	<1	4	0
Tin	ppm	ASTM D5185m >13	<1	<1	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	2	0
Manganese	ppm	ASTM D5185m	1	2	<1
Magnesium	ppm	ASTM D5185m	4	4	6
Calcium	ppm	ASTM D5185m	1466	1305	1407
Phosphorus	ppm	ASTM D5185m	406	362	389
Zinc	ppm	ASTM D5185m	454	397	438
Sulfur	ppm	ASTM D5185m	2444	2339	2336

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >200	57	27	5
Sodium	ppm	ASTM D5185m	1	5	<1
Potassium	ppm	ASTM D5185m >20	<1	4	<1

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	0	0
Nitration	Abs/cm	*ASTM D7624 >20	5.0	4.7	4.1
Sulfation	Abs/.1mm	*ASTM D7415 >30	15.2	15.3	14.7


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	9.5	9.2	8.7
Acid Number (AN)	mg KOH/g	ASTM D8045	0.29	0.55	0.37
Base Number (BN)	mg KOH/g	ASTM D2896	7.31	6.86	6.66




OIL ANALYSIS REPORT

Ferrous Alloys



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


Acid Number




FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.1	13.0	13.0

GRAPHS


Base Number




Iron (ppm)




Lead (ppm)




Aluminum (ppm)




Chromium (ppm)




Viscosity @ 100°C




Copper (ppm)




Silicon (ppm)



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0836320 **Received** : 14 Aug 2023
Lab Number : 05923544 **Diagnosed** : 15 Aug 2023
Unique Number : 10603491 **Diagnostician** : Doug Bogart
Test Package : MOB 2

OAK GROVE KS
 1150 E 700TH AVE
 ARCADIA, KS
 US 66711

Contact: KALEB WEAVER
 kaleb.weaver@cubedistrictenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: