




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
27318
 Component
Diesel Engine
 Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Elevated aluminum (Al) and/or lead (Pb) and potassium (K) levels in your metals analysis are likely a result of solder flux release into the lubricant and is common on new equipment/components. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KL0012009	KLM2339299	---
Sample Date	Client Info		25 Jul 2023	11 Apr 2023	---
Machine Age	mls	Client Info	41081	59328	---
Oil Age	mls	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			NORMAL	ATTENTION	---

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<1.0	<1.0	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >100	145	94	---
Chromium	ppm	ASTM D5185m >20	5	3	---
Nickel	ppm	ASTM D5185m >4	<1	<1	---
Titanium	ppm	ASTM D5185m	<1	<1	---
Silver	ppm	ASTM D5185m >3	<1	<1	---
Aluminum	ppm	ASTM D5185m >20	27	22	---
Lead	ppm	ASTM D5185m >40	0	<1	---
Copper	ppm	ASTM D5185m >330	11	8	---
Tin	ppm	ASTM D5185m >15	1	1	---
Vanadium	ppm	ASTM D5185m	0	0	---
Cadmium	ppm	ASTM D5185m	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	12	15	---
Barium	ppm	ASTM D5185m	0	0	---
Molybdenum	ppm	ASTM D5185m	62	60	---
Manganese	ppm	ASTM D5185m	2	1	---
Magnesium	ppm	ASTM D5185m	1103	1102	---
Calcium	ppm	ASTM D5185m	1170	1119	---
Phosphorus	ppm	ASTM D5185m	1056	1052	---
Zinc	ppm	ASTM D5185m	1344	1343	---
Sulfur	ppm	ASTM D5185m	3587	3671	---

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	16	14	---
Sodium	ppm	ASTM D5185m	19	6	---
Potassium	ppm	ASTM D5185m >20	76	65	---
Glycol	%	*ASTM D2982	NEG	NEG	---

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >3	1.9	1.6	---
Nitration	Abs/cm	*ASTM D7624 >20	17.5	15.5	---
Sulfation	Abs./1mm	*ASTM D7415 >30	40.3	35.7	---



OIL ANALYSIS REPORT








FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		3958	9387	---
Particles >6µm	ASTM D7647	>5000	2156	▲ 5114	---
Particles >14µm	ASTM D7647	>640	367	▲ 870	---
Particles >21µm	ASTM D7647	>160	124	▲ 293	---
Particles >38µm	ASTM D7647	>40	19	▲ 45	---
Particles >71µm	ASTM D7647	>10	2	5	---
Oil Cleanliness	ISO 4406 (c)	>19/16	18/16	▲ 20/17	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm *ASTM D7414	>25	50.2	40.7	---
Base Number (BN)	mg KOH/g ASTM D2896		5.97	10.34	---

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	NONE	---
Yellow Metal	scalar *Visual	NONE	NONE	NONE	---
Precipitate	scalar *Visual	NONE	NONE	NONE	---
Silt	scalar *Visual	NONE	NONE	NONE	---
Debris	scalar *Visual	NONE	NONE	NONE	---
Sand/Dirt	scalar *Visual	NONE	NONE	NONE	---
Appearance	scalar *Visual	NORML	NORML	NORML	---
Odor	scalar *Visual	NORML	NORML	NORML	---
Emulsified Water	scalar *Visual	>0.2	NEG	NEG	---
Free Water	scalar *Visual		NEG	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt ASTM D445		13.8	13.3	---

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0012009 **Received** : 14 Aug 2023
Lab Number : 05923567 **Diagnosed** : 16 Aug 2023
Unique Number : 10603514 **Diagnostician** : Jonathan Hester
Test Package : MOB 2 (Additional Tests: Glycol, PrtCount)

CITY & COUNTY HONOLULU
 99-999 IWAENA RD
 AIEA, HI
 US 96701
 Contact: CLYDE OMIJA
 comija@honolulu.gov
 T: (575)623-9952
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)