

# **PROBLEM SUMMARY**

Sample Rating Trend


ISO

Machine Id E-2 E-2

Component **Lube System** 

**MOBIL DTE OIL EXTRA HEAVY (--- GAL)** 

#### **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL					
Particles >4µm	ASTM D7647	>5000	<b>13598</b>						
Particles >6µm	ASTM D7647	>1300	<b>1523</b>						
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>1</b> 21/18/12						

**Customer Id: TESAUSTLC** Sample No.: TLC0000999 Lab Number: 05924187 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component if applicable.

## HISTORICAL DIAGNOSIS

25 May 2023 Diag: Jonathan Hester

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend







Machine Id E-2 E-2

Component

**Lube System** 

**MOBIL DTE OIL EXTRA HEAVY (--- GAL)** 

## **DIAGNOSIS**

#### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			May2023	Aug2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TLC0000999	TLC0001158	
Sample Date		Client Info		14 Aug 2023	25 May 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1	2	
Chromium	ppm	ASTM D5185m	>20	0	0	
Nickel	ppm	ASTM D5185m	>20	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>20	0	0	
Lead	ppm	ASTM D5185m	>20	0	4	
Copper	ppm		>20	<1	7	
Tin	ppm	ASTM D5185m	>20	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	3	
Molybdenum	ppm	ASTM D5185m		0	<1	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		<1	1	
Calcium	ppm	ASTM D5185m		104	9	
Phosphorus	ppm	ASTM D5185m		408	15	
Zinc	ppm	ASTM D5185m		512	12	
Sulfur	ppm	ASTM D5185m		10888	4918	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	12	15	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	0	<1	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>5000	<u> </u>		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14μm		ASTM D7647	>160	21		
Particles >21µm		ASTM D7647	>40	3		
Particles >38μm		ASTM D7647	>10	0		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u>^</u> 21/18/12		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.80	0.492	



## **OIL ANALYSIS REPORT**







Laboratory Sample No.

Lab Number **Unique Number** Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : TLC0000999 : 05924187 : 10604134

Received : 14 Aug 2023 Diagnosed Diagnostician

: 15 Aug 2023 : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**TESLA** 1 Tesla Road, BIW E58 Austin, TX

US 78725 Contact: Dave Mitchell davmitchell@tesla.com T: (260)226-1968

F: