




# PROBLEM SUMMARY

Sample Rating Trend




**WATER**




Machine Id  
**CARRIER LCOR JEFFERSON C2 (S/N 3802Q67307)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**CARRIER 68 (--- Oz)**

## COMPONENT CONDITION SUMMARY

### ▲ Non-ferrous Metals



### ▲ Water



## RECOMMENDATION

No corrective action is recommended at this time.  
 Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	MARGINAL
Tin	ppm	ASTM D5185m	>4	▲ 11	▲ 14	4
Water	%	ASTM D6304	>0.01	▲ 0.013	▲ 0.017	▲ 0.028
ppm Water	ppm	ASTM D6304	>100	▲ 137.9	▲ 178.0	▲ 289.6

Customer Id: CDSCRO  
 Sample No.: WC0713938  
 Lab Number: 05924373  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Angela Borella +1 800-237-1369  
[angela.borella@wearcheckusa.com](mailto:angela.borella@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 28 Jul 2022 Diag: Don Baldrige

#### WATER



No corrective action is recommended at this time. Resample at the next service interval to monitor. The tin level is abnormal. All other component wear rates are normal. There is a trace of moisture present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 26 Jul 2021 Diag: Don Baldrige

#### WATER



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 07 Aug 2020 Diag: Don Baldrige

#### WATER



No corrective action is recommended at this time. Resample at the next service interval to monitor. The tin level is abnormal. All other component wear rates are normal. There is a trace of moisture present in the oil. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**CARRIER LCOR JEFFERSON C2 (S/N 3802Q67307)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**CARRIER 68 (--- Oz)**

## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### ▲ Wear

The tin level is abnormal. All other component wear rates are normal.

### ▲ Contamination

There is a trace of moisture present in the oil. Elemental level of silicon (Si) above normal.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0713938</b>	WC0597013	WC0596986
Sample Date	Client Info		<b>02 Aug 2023</b>	28 Jul 2022	26 Jul 2021
Machine Age	hrs	Client Info	<b>6993</b>	24791	22954
Oil Age	hrs	Client Info	<b>6993</b>	24791	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	MARGINAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	<b>2</b>	2	<1
Chromium	ppm	ASTM D5185m >2	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	1	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m >3	<b>&lt;1</b>	2	0
Lead	ppm	ASTM D5185m >2	<b>&lt;1</b>	1	2
Copper	ppm	ASTM D5185m >8	<b>&lt;1</b>	2	<1
Tin	ppm	ASTM D5185m >4	<b>▲ 11</b>	<b>▲ 14</b>	4
Antimony	ppm	ASTM D5185m	<b>---</b>	---	3
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	<1	4
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Calcium	ppm	ASTM D5185m	<b>0</b>	0	<1
Phosphorus	ppm	ASTM D5185m	<b>568</b>	613	121
Zinc	ppm	ASTM D5185m	<b>0</b>	2	0
Sulfur	ppm	ASTM D5185m	<b>0</b>	8	23

## CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>11</b>	13	10
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185m >20	<b>2</b>	0	0
Water	%	ASTM D6304 >0.01	<b>▲ 0.013</b>	<b>▲ 0.017</b>	<b>▲ 0.028</b>
ppm Water	ppm	ASTM D6304 >100	<b>▲ 137.9</b>	<b>▲ 178.0</b>	<b>▲ 289.6</b>

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	<b>0.057</b>	0.063	0.086



# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	55.9	61.5	59.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0713938 **Received** : 14 Aug 2023  
**Lab Number** : 05924373 **Diagnosed** : 16 Aug 2023  
**Unique Number** : 10604320 **Diagnostician** : Angela Borella  
**Test Package** : IND 2

**CDS MECHANICAL SERVICES INC**  
 1654 CROFTON BLVD, SUITE 9  
 CROFTON, MD  
 US 21114  
 Contact: KENNY COMBA  
 kcomba@cdsmechanical.net  
 T: (410)451-7157  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)