



FUEL REPORT


Sample Rating Trend

NORMAL



Machine Id
RAND BLVD GEN - SARASOTA COUNTY

Component
Tank Diesel Fuel
Fluid
NOT GIVEN (200 GAL)



DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WCDF4456	---	---
Sample Date	Client Info	08 Aug 2023	---	---
Machine Age	mls	Client Info	0	---
Sample Status			NORMAL	---

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500	L4.0	---
Visc @ 40°C	cSt	ASTM D445	2.4	---

SULFUR CONTENT

method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	0	---
Sulfur (UVF)	ppm	ASTM D5453	12	---



CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0
Sodium	ppm	ASTM D5185m	<0.1	0
Potassium	ppm	ASTM D5185m	<0.1	<1
Water	%	ASTM D6304	<0.05	0.004
ppm Water	ppm	ASTM D6304	<500	45.4
% Gasoline	%	*In-House	<0.50	0.0
% Biodiesel	%	*In-House	<20.0	0.0

HEAVY METALS

method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0
Nickel	ppm	ASTM D5185m	<0.1	0
Lead	ppm	ASTM D5185m	<0.1	0
Vanadium	ppm	ASTM D5185m	<0.1	0
Iron	ppm	ASTM D5185m	<0.1	0
Calcium	ppm	ASTM D5185m	<0.1	<1
Magnesium	ppm	ASTM D5185m	<0.1	0
Phosphorus	ppm	ASTM D5185m	<0.1	1
Zinc	ppm	ASTM D5185m	<0.1	0




SAMPLE IMAGES

method	limit/base	current	history1	history2
Color			no image	no image
Bottom			no image	no image



FUEL REPORT

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WCDF4456 **Received** : 15 Aug 2023
Lab Number : 05925199 **Diagnosed** : 21 Aug 2023
Unique Number : 10605146 **Diagnostician** : Doug Bogart
Test Package : DF-5 (Additional Tests: Screen, Sulphur-Active)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

TANK WIZARDS
 1511 MASTERS RD NW
 PALM BAY, FL
 US 32907
 Contact: WENDALL STRODERD
 wendall@tankwizards.com
 T: (321)427-5149
 F: (321)574-4131