

PROBLEM SUMMARY

Sample Rating Trend

ISO

Machine Id


KAESER BSD50 6991100 (S/N 1111)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	NORMAL					
Particles >6µm	ASTM D7647	>1300	<u> </u>	429					
Particles >14μm	ASTM D7647	>80	<u> </u>	41					
Particles >21µm	ASTM D7647	>20	<u> </u>	23					
Oil Cleanliness	ISO 4406 (c)	>17/13	18/14	18/16/13					

Customer Id: SRCTULOK Sample No.: KC108735 Lab Number: 05925453 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

Action Status Date Done By Description Change Fluid --- ? Oil and filter change at the time of sampling has been noted. Change Filter --- ? Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

01 Jun 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

DODT

Sample Rating Trend

ISO

Machine Id

KAESER BSD50 6991100 (S/N 1111)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun2022	Jul2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC108735	KCP50958	
Sample Date		Client Info		19 Jul 2023	01 Jun 2022	
Machine Age	hrs	Client Info		8785	5872	
Oil Age	hrs	Client Info		5872	5872	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ATTENTION	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	5	13	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	7	6	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		1	2	
Zinc	ppm	ASTM D5185m		22	79	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	
Sodium	ppm	ASTM D5185m		3	3	
Potassium	ppm	ASTM D5185m	>20	3	0	
Water	%	ASTM D6304	>0.05	0.010	0.013	
ppm Water	ppm	ASTM D6304	>500	104.6	132.5	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		7581	2067	
Particles >6µm		ASTM D7647	>1300	<u> </u>	429	
Particles >14μm		ASTM D7647	>80	<u> </u>	41	
Particles >21µm		ASTM D7647	>20	<u>^</u> 27	23	
Particles >38μm		ASTM D7647	>4	2	3	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>17/13	▲ 18/14	18/16/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.36

0.36



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: KC108735 : 05925453

: 10605400 : IND 2

Received : 15 Aug 2023 Diagnosed

: 17 Aug 2023 : Jonathan Hester Diagnostician

US 74107 Contact: K. GUILLORY kguillory@sandrcompression.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

TULSA, OK

T: F: