


# PROBLEM SUMMARY


Machine Id  
**BT-FOR-A7 (S/N TANK FT7 AGITATOR)**  
Component  
**Gearbox**  
Fluid  
**SHELL OMALA S2 GX 220 (--- GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

Particle Trend



## RECOMMENDATION

Filter oil if possible using B6=75 filter media or better. If filtration is not possible consider changing oil. No other action required at this time. Resample at next normal interval.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ATTENTION	SEVERE
Particles >4µm	ASTM D7647	>20000	▲ 158644	---	---
Particles >6µm	ASTM D7647	>5000	● 75548	---	---
Particles >14µm	ASTM D7647	>640	● 6914	---	---
Particles >21µm	ASTM D7647	>160	● 1363	---	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	● 24/23/20	---	---

Customer Id: MOMBAY  
Sample No.: PLS0000562  
Lab Number: 05925995  
Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Mike Johnson +1 (615)771-6030  
[mike.johnson@amrri.com](mailto:mike.johnson@amrri.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

### 01 May 2023 Diag: Mike Johnson

#### VISUAL METAL



Ferrous wear rate has returned to the typical trend. There is sufficient visual evidence (above 40 micron particles) that a particle count could not be performed. If this unit is being sampled from a drain line RESAMPLE and be sure to flush the drain line before collecting the sample. The unit should be filtered using B6=75 quality filter media to remove particulate and wear debris. Fe wear rate is within the typical historical range for this drive. Fe wear rates are always higher with drives given their operating contact modes, but filtration helps to control the wear rate. Particle count could not be provided due to the debris in the oil. Filtration is strongly recommended. Fluid health properties suggest oil is acceptable for continued use.

view report



### 26 Jan 2023 Diag: Mike Johnson

#### WEAR



Investigate machine for signs of wear using predictive maintenance technologies such as vibration and thermal trending. Consider filtering oil using B6=75 filter or better. If oil cannot be filtered, consider flushing and changing oil. Iron wear particles are substantially elevated from previous samples. This can indicate accelerated wear. Visible contamination was present in the sample. Fluid health is acceptable for continued use provided that contamination can be brought under control.

view report



### 18 Oct 2022 Diag: Mike Johnson

#### VISUAL METAL




Oil cleanliness tests were not conducted due to visible particulate in the sample. Filter oil if possible and resample oil. Investigate possible sources of contamination. Wear particles are low and steady. Oil cleanliness tests were not conducted due to visible particulate in the sample. Fluid health is acceptable for continued use provided that contamination is brought under control.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**BT-FOR-A7 (S/N TANK FT7 AGITATOR)**

Component

**Gearbox**

Fluid

**SHELL OMALA S2 GX 220 (--- GAL)**

## DIAGNOSIS

### Recommendation

Filter oil if possible using B6=75 filter media or better. If filtration is not possible consider changing oil. No other action required at this time. Resample at next normal interval.

### Wear

Wear particles are steady.

### Contamination

Particle contamination is highly elevated. Filtration can help extend machine life.

### Fluid Condition

Fluid health is acceptable for continued use provided that contamination can be brought under control.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PLS0000562</b>	PLS0000707	PLS0000632
Sample Date	Client Info		<b>09 Aug 2023</b>	01 May 2023	26 Jan 2023
Machine Age	mths	Client Info	<b>0</b>	0	3
Oil Age	mths	Client Info	<b>0</b>	3	0
Oil Changed	Client Info		<b>N/A</b>	Changed	N/A
Sample Status			<b>SEVERE</b>	ATTENTION	SEVERE

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		<b>44</b>	79	95
Iron	ppm	ASTM D5185m >200	<b>48</b>	53	154
Chromium	ppm	ASTM D5185m >15	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m >15	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	<1	0
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	0	<1
Tin	ppm	ASTM D5185m >25	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 6.2	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 0.0	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>&lt;1</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	1
Magnesium	ppm	ASTM D5185m 0	<b>4</b>	0	2
Calcium	ppm	ASTM D5185m 0.0	<b>5</b>	<1	4
Phosphorus	ppm	ASTM D5185m 290	<b>273</b>	306	297
Zinc	ppm	ASTM D5185m 3.8	<b>14</b>	0	12
Sulfur	ppm	ASTM D5185m 8167	<b>10188</b>	13424	9198

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>2</b>	1	<1
Sodium	ppm	ASTM D5185m	<b>0</b>	<1	0
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	1






## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0</b>	0	0.1
Nitration	Abs/cm	*ASTM D7624	<b>2.9</b>	2.9	3.2
Sulfation	Abs/.1mm	*ASTM D7415	<b>11.8</b>	12.4	12.3

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>158644</b>	---	---
Particles >6µm	ASTM D7647	>5000	<b>75548</b>	---	---
Particles >14µm	ASTM D7647	>640	<b>6914</b>	---	---
Particles >21µm	ASTM D7647	>160	<b>1363</b>	---	---
Particles >38µm	ASTM D7647	>40	<b>23</b>	---	---
Particles >71µm	ASTM D7647	>10	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>24/23/20</b>	---	---

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs./1mm	*ASTM D7414		<b>2.8</b>	3.0	2.9
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.45</b>	0.48	0.51





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	▲ HEAVY	▲ MODER
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	● MODER
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	<b>210</b>	210	212

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PLS0000562 **Received** : 16 Aug 2023  
**Lab Number** : 05925995 **Diagnosed** : 23 Aug 2023  
**Unique Number** : 10605942 **Diagnostician** : Mike Johnson  
**Test Package** : PLANT ( Additional Tests: FT-IR, PrtCount )

**HEXION - BAYTOWN PLANT**  
 8450 WEST BAY RD  
 BAYTOWN, TX  
 US 77520  
 Contact: BILL MINER  
 bill.miner@momentive.com  
 T:  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)