


PROBLEM SUMMARY

Sample Rating Trend



ISO




Machine Id
BT-F01-B1 (S/N B1 RECYCLE BLOWER)

Component
Outboard Blower

Fluid
SHELL TELLUS S2 MX 100 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Oil contamination is improved but can still benefit from more filtration. Current oil contamination levels are on par with new unfiltered oil. Filter oil if possible using B6=75 filter media or better. No other action recommended at this time. Resample at next normal interval.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	SEVERE	ABNORMAL
Particles >4µm	ASTM D7647	>2500	▲ 5121	---	▲ 3214
Particles >6µm	ASTM D7647	>640	▲ 1017	---	556
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 20/17/13	---	▲ 19/16/11

Customer Id: MOMBAY
Sample No.: PLS0000480
Lab Number: 05926003
Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:
Mike Johnson +1 (615)771-6030
mike.johnson@amrri.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

01 May 2023 Diag: Mike Johnson

VISUAL METAL



Schedule an oil change immediately if possible. Viscosity is substantially out of range, and low enough to be harmful to the machine. IF an oil change cannot be done promptly then drain small amounts and top up the unit multiple times with the proper fluid until half the oil sump capacity has been enhanced with new MX 100. Resample following this activity. The wear rate is still low and steady. Particle count could not be provided due to the debris in the oil. Filtration is strongly recommended. The viscosity is substantially diminished. Additives are substantially diminished. The unit has likely been topped up with an incorrect selection. Replace as soon as possible.

view report



26 Jan 2023 Diag: Mike Johnson

ISO



Oil contamination is improved but can still benefit from more filtration. Current oil contamination levels are on par with new unfiltered oil. Filter oil if possible using B6=75 filter media or better. No other action recommended at this time. Resample at next normal interval. Wear particles are low and acceptable. Particle contamination is elevated. Filtration can help extend machine life. Fluid health is acceptable for continued use.

view report



17 Oct 2022 Diag: Mike Johnson

ISO




Particle counts are elevated. Filter oil if possible with B6=75 filter media or better. No other action recommended at this time. Resample at next normal interval. Wear particles are low and acceptable. Particle contamination is slightly elevated. Filter oil if possible. Fluid health is acceptable for continued use.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
BT-F01-B1 (S/N B1 RECYCLE BLOWER)

Component
Outboard Blower

Fluid
SHELL TELLUS S2 MX 100 (--- GAL)

DIAGNOSIS

Recommendation

Oil contamination is improved but can still benefit from more filtration. Current oil contamination levels are on par with new unfiltered oil. Filter oil if possible using B6=75 filter media or better. No other action recommended at this time. Resample at next normal interval.

Wear

Wear particles are low and acceptable.

Contamination

Particle contamination is elevated. Filtration can help extend machine life.

Fluid Condition

Fluid health is acceptable for continued use.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PLS0000480	PLS0000710	PLS0000639
Sample Date	Client Info	09 Aug 2023	01 May 2023	26 Jan 2023
Machine Age	mths	Client Info	0	3
Oil Age	mths	Client Info	6	0
Oil Changed	Client Info	N/A	Not Chngd	N/A
Sample Status		ABNORMAL	SEVERE	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184	12	12	13	
Iron	ppm	ASTM D5185m >20	<1	3	0
Chromium	ppm	ASTM D5185m >20	0	0	0
Nickel	ppm	ASTM D5185m >20	0	<1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >20	0	<1	0
Lead	ppm	ASTM D5185m >20	0	2	0
Copper	ppm	ASTM D5185m >20	<1	2	6
Tin	ppm	ASTM D5185m >20	0	<1	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	1	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	0	<1	0
Magnesium	ppm	ASTM D5185m	62	2	57
Calcium	ppm	ASTM D5185m	1	4	9
Phosphorus	ppm	ASTM D5185m	287	▲ 69	282
Zinc	ppm	ASTM D5185m	355	▲ 7	348
Sulfur	ppm	ASTM D5185m	808	3013	723

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	0	0	<1
Sodium	ppm	ASTM D5185m	0	2	0
Potassium	ppm	ASTM D5185m >20	<1	1	<1

INFRA-RED


method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844	0	0	0
Nitration	Abs/cm	*ASTM D7624	1.8	2.4	2.0
Sulfation	Abs/.1mm	*ASTM D7415	10.3	11.2	10.4

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >2500	▲ 5121	---	▲ 3214
Particles >6µm	ASTM D7647 >640	▲ 1017	---	556
Particles >14µm	ASTM D7647 >80	64	---	17
Particles >21µm	ASTM D7647 >20	16	---	2
Particles >38µm	ASTM D7647 >4	2	---	0
Particles >71µm	ASTM D7647 >3	0	---	0
Oil Cleanliness	ISO 4406 (c) >18/16/13	▲ 20/17/13	---	▲ 19/16/11

OIL ANALYSIS REPORT


Particle Trend




PQ




Acid Number



Viscosity @ 40°C



PQ



FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm	*ASTM D7414	1.9	2.7	1.9
Acid Number (AN)	mg KOH/g	ASTM D8045	0.33	0.19	0.44


VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	MODER	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	97.7	51.68	100

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color

Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PLS0000480 **Received** : 16 Aug 2023
Lab Number : **05926003** **Diagnosed** : 23 Aug 2023
Unique Number : 10605950 **Diagnostician** : Mike Johnson
Test Package : PLANT (Additional Tests: FT-IR)

HEXION - BAYTOWN PLANT
 8450 WEST BAY RD
 BAYTOWN, TX
 US 77520
 Contact: PAT BELL
 pat.bell@momentive.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: