

# **OIL ANALYSIS REPORT**

Sample Rating Trend

NORMAL



# KAESER 1211

Component

Compressor

HIGH PERFORMANCE LUBRICANTS FG ISO 46 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

50 40 ( GAL)				Jul2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		HPL0001376		
Sample Date		Client Info		05 Jul 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		3000		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	Ν	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	6		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	0		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	3		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m	1	0		
Phosphorus	ppm	ASTM D5185m	635	77		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m	2225	400		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.1	0.94		



## **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No. Lab Number

**Unique Number** 

: HPL0001376 : 05926257

: 10606204 Test Package : MOB 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 16 Aug 2023 Recieved Diagnosed : 17 Aug 2023

: Jonathan Hester Diagnostician

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

FLORIDA TECHNICAL PRODUCTS INC

1777 SHOAL CREEK CIRCLE GREEN COVE SPRINGS, FL

US 32043

Contact: DANNY HAMILTON dan@floridatechnicalproducts.com

T: (904)703-6057 F:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)