


FUEL REPORT

Sample Rating Trend

NORMAL



Area
[X47388]
 Machine Id
VOLVO A25G 752635
 Component
Diesel Fuel
 Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample. No corrective action is recommended at this time.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no indication of any contamination in the fuel.

Fuel Condition

The condition of the fuel is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			VCP427023	VCP407872	---
Sample Date	Client Info			09 Aug 2023	16 May 2023	---
Machine Age	hrs	Client Info		1369	772	---
Sample Status				NORMAL	ABNORMAL	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		2.57	2.5	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0	8	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	<1	---
Sodium	ppm	ASTM D5185m	<0.1	0	0	---
Potassium	ppm	ASTM D5185m	<0.1	<1	<1	---
Water	%	ASTM D6304	<0.05	0.004	0.004	---
ppm Water	ppm	ASTM D6304	<500	40.0	44.8	---





HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	0	---
Nickel	ppm	ASTM D5185m	<0.1	0	<1	---
Lead	ppm	ASTM D5185m	<0.1	<1	0	---
Vanadium	ppm	ASTM D5185m	<0.1	0	0	---
Iron	ppm	ASTM D5185m	<0.1	0	0	---
Calcium	ppm	ASTM D5185m	<0.1	0	<1	---
Magnesium	ppm	ASTM D5185m	<0.1	0	<1	---
Phosphorus	ppm	ASTM D5185m	<0.1	<1	0	---
Zinc	ppm	ASTM D5185m	<0.1	0	0	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

Color						no image
Bottom						no image

FUEL REPORT

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : VCP427023 **Received** : 16 Aug 2023
Lab Number : 05926506 **Diagnosed** : 18 Aug 2023
Unique Number : 10606453 **Diagnostician** : Jonathan Hester
Test Package : MOB 1 (Additional Tests: KF)

SCOTT EQUIPMENT COMPANY LLC - Lake Charles
 PO BOX 16955
 LAKE CHARLES, LA
 US 70616
 Contact: SAMANTHA SOILEAU
 ssoileau@scottcompanies.com
 T: (337)433-9811
 F: (318)433-6623

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)